

Sampling Results Regarding the Influence on the Water Leak at a Tank in the H4 area in Fukushima Daiichi Nuclear Power Station (Around the H4 Area)

Unit: Bq/L

	Groundwater around H4 area					
	E-1	E-2	E-3	E-4	E-5	E-6
Date of Sampling	Sep 18, 2013	Sep 18, 2013	Sep 18, 2013	Sep 18, 2013		
Time of sampling	10:45 AM	10:50 AM	11:00 AM	10:55 AM		
All β	270	32	570	ND(21)		
H-3 (Approx. 12 years)	Under analysis	Under analysis	Under analysis	Under analysis		

* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

