Nuclides Analysis Result of the Sub-drain Water in the Surroundings of the Central Radioactive Waste Treatment Facility

I-131(Bq/cm³)

Sampling	After tra	ınsfer																			
Location	Feb 17	Feb 18	Feb 19	Feb 20	Feb 21	Feb 22	Feb 23	Feb 24	Feb 25	Feb 26	Feb 27	Feb 28	Mar 1	Mar 2	Mar 3	Mar 4	Mar 5	Mar 6	Mar 7	Mar 8	
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	-	ND	-	-	-	-	-	-	ND	-	-	-	-	-	-	ND	-	-	-	-	
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	

Cs-134(Bq/cm³)

Sampling																					
Location	Feb 17	Feb 18	Feb 19	Feb 20	Feb 21	Feb 22	Feb 23	Feb 24	Feb 25	Feb 26	Feb 27	Feb 28	Mar 1	Mar 2	Mar 3	Mar 4	Mar 5	Mar 6	Mar 7	Mar 8	
	ND	ND	ND	0.02	ND	ND	ND	ND	ND												
	ND	ND	ND	ND	ND	ND	ND	ND	ND												
	ND	ND	ND	ND	ND	ND	ND	ND	ND												
	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
	ND	ND	ND	ND	ND	ND	ND	ND	ND												
	-	ND	-	-	-	-	-	-	ND	-	-	-	-	-	-	ND	-	-	-	-	
	0.089	0.085	0.1	0.052	0.099	0.12	0.092	0.0818	0.038	0.082	0.084	0.095	0.1	0.085	0.06	0.057	0.023	0.13	0.12	0.075	
	ND	ND	ND	ND	ND	ND	ND	ND	ND												
	ND	ND	ND	ND	ND	ND	ND	ND	ND												

Cs-137(Bq/cm³)

Sampling																					
Location	Feb 17	Feb 18	Feb 19	Feb 20	Feb 21	Feb 22	Feb 23	Feb 24	Feb 25	Feb 26	Feb 27	Feb 28	Mar 1	Mar 2	Mar 3	Mar 4	Mar 5	Mar 6	Mar 7	Mar 8	
	ND	ND	ND	0.049	ND	ND	ND	ND	ND												
	ND	ND	ND	ND	ND	ND	ND	ND	ND												
	ND	ND	ND	ND	ND	ND	ND	ND	ND												
	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
	ND	ND	ND	ND	ND	ND	ND	ND	ND												
	-	ND	-	-	-	-	-	-	ND	-	-	-	-	-	-	ND	-	-	-	-	
	0.15	0.15	0.18	0.077	0.16	0.19	0.19	0.14	0.06	0.16	0.17	0.17	0.16	0.17	0.089	0.11	0.052	0.23	0.22	0.15	
	ND	ND	ND	ND	ND	ND	ND	ND	ND												
	ND	ND	ND	ND	ND	ND	ND	ND	ND												

- * Hyphen "-" indicates that neither sampling nor measurement was implemented.
- * was selected as a sampling location in the upstream of groundwater (sampling done once a week starting from April 29, 2011) since it became unable to do sampling at
- * Sampling at (located in the downstream of the groundwater) has been done since May 26, 2011.
- * Samping at since May 30, 2011
- * Sampling at has been done since August 2, 2011
- * "ND" indicates that the measurement result is below the detection limit.

I-131: Approx. 0.01Bq/cm³, Cs-134: Approx.0.02Bq/cm³, Cs-137: Approx.0.02Bq/cm³ (March 8, 2013)

As the detection limit may vary depending on the detectors and sample properties, there are cases where nuclides below the detection limit are detected.

<Place of Sampling>

Southeast of Unit 4 Turbine Building

Northeast of the Process Main Building

Southeast of the Process Main Building

Southwest of the Process Main Building

South Part of the Miscellaneous Solid Waste Volume Reduction Treatment Building

Southwest Part of the On-site Bunker Building

West Side of the Incineration Workshop Building

North Part of the Miscellaneous Solid Waste Volume Reduction Treatment Building Southeast Part of the On-site Bunker Building