

**Nuclides Analysis Result of the Sub-drain Water in the Surroundings of the Central Radioactive Waste Treatment Facility**

I-131(Bq/cm<sup>3</sup>)

Sampling Location	Aug 18	Aug 19	Aug 20	Aug 21	Aug 22	Aug 23	Aug 24	Aug 25	Aug 26	Aug 27	Aug 28	Aug 29	Aug 30	Aug 31	Sep 1	Sep 2	Sep 3	Sep 4			
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND			
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND			
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND			
	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND			
	-	ND	-	-	-	-	-	-	ND	-	-	-	-	-	-	ND	-	-			
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND			
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND			
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND			

Cs-134(Bq/cm<sup>3</sup>)

Sampling Location	Aug 18	Aug 19	Aug 20	Aug 21	Aug 22	Aug 23	Aug 24	Aug 25	Aug 26	Aug 27	Aug 28	Aug 29	Aug 30	Aug 31	Sep 1	Sep 2	Sep 3	Sep 4			
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND			
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND			
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND			
	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND			
	-	ND	-	-	-	-	-	-	ND	-	-	-	-	-	-	ND	-	-			
	0.062	0.072	0.043	0.035	0.042	0.051	0.05	0.044	0.034	0.06	0.058	0.073	0.053	0.061	0.062	0.068	0.058	0.053			
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND			
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND			

Cs-137(Bq/cm<sup>3</sup>)

Sampling Location	Aug 18	Aug 19	Aug 20	Aug 21	Aug 22	Aug 23	Aug 24	Aug 25	Aug 26	Aug 27	Aug 28	Aug 29	Aug 30	Aug 31	Sep 1	Sep 2	Sep 3	Sep 4			
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND			
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND			
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND			
	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND			
	-	ND	-	-	-	-	-	-	ND	-	-	-	-	-	-	ND	-	-			
	0.13	0.13	0.085	0.1	0.12	0.13	0.12	0.11	0.091	0.13	0.1	0.12	0.11	0.14	0.14	0.14	0.11	0.097			
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND			
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND			

\* Hyphen "-" indicates that neither sampling nor measurement was implemented.  
 \* was selected as a sampling location in the upstream of groundwater (sampling done once a week starting from April 29, 2011) since it became unable to do sampling at .  
 \* Sampling at (located in the downstream of the groundwater) has been done since May 26, 2011.  
 \* Sampling at since May 30, 2011  
 \* Sampling at has been done since August 2, 2011  
 \* "ND" indicates that the measurement result is below the detection limit.  
 I-131: Approx. 0.009Bq/cm<sup>3</sup>, Cs-134: Approx.0.01Bq/cm<sup>3</sup>, Cs-137: Approx.0.02Bq/cm<sup>3</sup> (September 4, 2013)  
 As the detection limit may vary depending on the detectors and sample properties, there are cases where nuclides below the detection limit are detected.

- <Place of Sampling>  
 Southeast of Unit 4 Turbine Building  
 Northeast of the Process Main Building  
 Southeast of the Process Main Building  
 Southwest of the Process Main Building  
 South Part of the Miscellaneous Solid Waste Volume Reduction Treatment Building  
 Southwest Part of the On-site Bunker Building  
 West Side of the Incineration Workshop Building  
 North Part of the Miscellaneous Solid Waste Volume Reduction Treatment Building  
 Southeast Part of the On-site Bunker Building