

Analysis Results of Accumulated Water at Unit 2, 3 Seaside Trench in Fukushima Daiichi Nuclear Power Station

Unit: Bq/L (excludes chloride)

	Unit 2			Unit 3		
	Seawater piping trench vertical shaft C (water depth: 1m) (Unit 2 A)	Seawater piping trench vertical shaft C (water depth: 7m) (Unit 2 A)	Seawater piping trench vertical shaft C (water depth: 13m) (Unit 2 A)	Seawater piping trench vertical shaft C (water depth: 1m) (Unit 3 A)	Seawater piping trench vertical shaft C (water depth: 7m) (Unit 3 A)	Seawater piping trench vertical shaft C (water depth: 13m) (Unit 3 A)
Date of sampling	Jul 31, 2013	Jul 31, 2013	Jul 31, 2013	Jul 31, 2013	Jul 31, 2013	Jul 31, 2013
Time of sampling	10:30 AM	10:30 AM	10:30 AM	10:30 AM	10:30 AM	10:30 AM
Chloride (ppm)	700	700	7,500	16,000	17,000	17,000
Cs-134 (Approx. 2 years)	110,000,000	110,000,000	300,000,000	13,000,000	10,000,000	12,000,000
Cs-137 (Approx.30 years)	230,000,000	240,000,000	650,000,000	26,000,000	22,000,000	24,000,000
The other Y						
All β	330,000,000	330,000,000	520,000,000	32,000,000	34,000,000	34,000,000
H-3 (Approx. 12 years)	2,400,000	2,400,000	4,600,000	360,000	340,000	350,000

* Data announced this time is provided in a thick-frame. The other data was announced on August 1.

* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.