

Sampling Results Regarding the Influence on the Water Leak at a Tank in the H4 area in Fukushima Daiichi Nuclear Power Station (Around the H4 Area)

<Reference>
 January 3, 2014
 Tokyo Electric Power Company

Unit: Bq/L

	Groundwater around H4 area											
	E-1	E-2	E-3	E-4	E-5	E-6	E-7	E-8	E-9	E-10	Well point	F-1
Date of Sampling	Jan 1, 2014	Jan 1, 2014	Jan 1, 2014	Jan 1, 2014	Jan 1, 2014	Jan 1, 2014	Jan 1, 2014	Jan 1, 2014	Jan 1, 2014	Jan 1, 2014		
Time of sampling	10:10 AM	10:05 AM	10:26 AM	10:16 AM	10:08 AM	11:23 AM	10:55 AM	11:01 AM	10:38 AM			
Gross β	14,000	ND(18)	ND(18)	ND(18)	ND(18)	ND(18)	ND(18)	ND(18)	65			
H-3 (Approx. 12 years)	420,000	320	1,800	1,600	2,200	350	400	1600	13,000			

* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

<Reference> The Highest Dose Until the Previous Measurement

	E-1	E-2	E-3	E-4	E-5	E-6
Gross β	10,000 [11/10]	650 [9/4]	570 [9/18]	1,300 [9/15]	100 [9/24]	46 [9/20]
H-3 (Approx. 12 years)	90,000 [10/17]	530 [10/5]	2,200 [12/31]	2,200 [12/7,12/16,12/18]	3,100 [11/10,11/13]	350 [12/18]

	E-7	E-8	E-9	E-10	Well point	F-1
Gross β	ND	17 [10/3]	730 [12/27]	28 [11/6]	16,000 [11/28]	19 [12/27]
H-3 (Approx. 12 years)	840 [10/9]	2,300 [11/13]	51,000 [11/25]	53,000 [12/28]	190,000 [11/30]	720 [12/31]

Unit: Bq/L, sampling date is provided in parentheses.

