

## Sampling Results Regarding the Influence on the Water Leak at a Tank in the H4 area in Fukushima Daiichi Nuclear Power Station (Around the H4 Area)

<Reference>  
January 10, 2014  
Tokyo Electric Power Company

Unit: Bq/L

	Groundwater around H4 area											
	E-1	E-2	E-3	E-4	E-5	E-6	E-7	E-8	E-9	E-10	Well point	F-1
Date of Sampling	Jan 8, 2014	Jan 8, 2014	Jan 8, 2014	Jan 8, 2014	Jan 8, 2014	Jan 8, 2014	Jan 8, 2014	Jan 8, 2014	Jan 8, 2014	Jan 8, 2014		
Time of sampling	11:05 AM	11:00 AM	10:37 AM	10:33 AM	10:30 AM	10:04 AM	10:17 AM	10:24 AM	10:54 AM			
Gross β	9,000	ND(17)	ND(17)	24	ND(17)	ND(17)	ND(18)	ND(17)	24			
H-3 (Approx. 12 years)	17,000	350	1,800	950	1,800	240	340	1500	9,500			

\* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

<Reference> The Highest Dose Until the Previous Measurement

	E-1	E-2	E-3	E-4	E-5	E-6
Gross β	710,000 [11/10]	650 [9/4]	570 [9/18]	1,300 [9/15]	100 [9/24]	46 [9/20]
H-3 (Approx. 12 years)	790,000 [10/17]	530 [10/5] <1/3>	2,500<1/4>	2,200 [12/7,12/16, 12/18]	3,100 [11/10,11/13]	350 [12/18] <1/1>
	E-7	E-8	E-9	E-10	Well point	F-1
Gross β	ND	17 [10/3]	730 [12/27]	28 [11/6]	16,000 [11/28]	19[12/27]
H-3 (Approx. 12 years)	840 [10/9]	2,300 [11/13]	51,000 [11/25]	53,000 [12/31]	190,000 [11/30]	720[12/31]

Unit: Bq/L, sampling date is provided in parentheses.

