

**Nuclide Analysis Results of the Underground Bypass (Investigation Holes/Pumping Well) and the Sea Side Observation Holes  
(As of January 14, 2014)**

	Underground bypass investigation holes			Underground bypass pumping well				Sea side observation holes							
	a	b	c	1	2	3	4	①	②	③	④	⑤	⑥	⑦	⑧
Sampled time		8:51 AM	9:10 AM	10:12 AM	9:58 AM	10:02 AM	10:05 AM	8:43 AM	9:12 AM	9:38 AM	9:38 AM				
Chloride concentration (ppm)		8	10	12	23	54	10	9	5	8	10				
Tritium (Bq/cm <sup>3</sup> )		Under analysis	Under analysis	Under analysis	Under analysis	Under analysis	Under analysis	Under analysis	Under analysis	Under analysis	Under analysis				
All β(Bq/cm <sup>3</sup> )		<2.8E-2	<2.8E-2	<1.5E-2	<1.5E-2	<1.5E-2	<1.5E-2	<2.8E-2	<2.8E-2	<2.8E-2	<2.8E-2				

Half-life period Tritium: Approx. 12 years

(Note 1) O.OE±O is the same as O.O x 10<sup>+0</sup>.

(Note 2) The figures written next to "<" indicate the detection limit when the measurement result is below the detection limit.