

**Tritium Analysis Results of the Underground Bypass (Investigation Holes/Pumping Well) and the Sea Side Observation Holes
(As of June 23 and 24, 2014)**

	Underground bypass investigation holes			Sea side observation holes							
	a	b	c	①	②	③	④	⑤	⑥	⑦	⑧
	Jun 24, 2014						Jun 23, 2014				
Sampled time		9:50 AM	9:33 AM	10:26 AM	10:51 AM	9:07 AM	10:11 AM	9:43 AM	9:26 AM	10:03 AM	9:08 AM
Chloride concentration (ppm)		8	13	9	7	9	12	8	9	13	11
Tritium (Bq/cm ³)		1.8E-1	<9.1E-3	4.6E-2	3.6E-2	4.0E-1	1.6E+0	4.9E-2	8.6E-2	4.2E-2	1.2E-1
All β(Bq/cm ³)		<3.0E-2	<3.0E-2	<3.0E-2	<3.0E-2	<3.0E-2	<3.0E-2	<3.0E-2	<3.0E-2	<3.0E-2	<3.0E-2

Half-life period Tritium: Approx. 12 years

(Note 1) Nuclide analysis results other than tritium were announced on June 24 and 25.

(Note 2) O.OE±O is the same as O.O x 10^{±0}.

(Note 3) The figures written next to "<" indicate the detection limit when the measurement result is below the detection limit.