

Sampling Results Regarding the Influence on the Water Leak at a Tank in the H4 area in Fukushima Daiichi Nuclear Power Station (Pump Well)

<Reference>
 April 3, 2014
 Tokyo Electric Power Company

Unit: Bq/L

	Pump wells of the groundwater bypass							
	No.5	No.6	No.7	No.8	No.9	No.10	No.11	No.12
Date of Sampling	Apr 1, 2014	Apr 1, 2014	Apr 1, 2014	Apr 1, 2014	Apr 1, 2014	Apr 1, 2014	Apr 1, 2014	Apr 1, 2014
Time of sampling	11:02 AM	11:06 AM	11:11 AM	11:14 AM	11:18 AM	11:21 AM	11:32 AM	11:35 AM
All β	ND(16)	ND(16)	ND(16)	ND(16)	ND(16)	ND(16)	ND(16)	ND(16)
H-3 (Approx. 12 years)	46	200	620	51	69	150	340	1200

* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

<Reference> The Highest Dose Until the Previous Measurement

	No.5	No.6	No.7	No.8
All β	ND	ND	ND	ND
H-3 (Approx. 12 years)	48 <3/25>	210 <3/25>	620 [11/19]	97 [11/26]

	No.9	No.10	No.11	No.12
All β	ND	ND	ND	ND
H-3 (Approx. 12 years)	100 [11/26,12/3]	330 [9/1,9/2]	480 [10/22,11/5]	1,200 <3/4,3/11,3/25>

Unit: Bq/L, sampling date is provided in parentheses.
 []: 2013, < >: 2014

