

# Sampling Results Regarding the Influence on the Water Leak at a Tank in the H4 area in Fukushima Daiichi Nuclear Power Station (Pump Well)

<Reference>  
 April 10, 2014  
 Tokyo Electric Power Company

Unit: Bq/L

	Pump wells of the groundwater bypass							
	No.5	No.6	No.7	No.8	No.9	No.10	No.11	No.12
Date of Sampling	Apr 8, 2014	Apr 8, 2014	Apr 8, 2014	Apr 8, 2014	Apr 8, 2014	Apr 8, 2014	Apr 8, 2014	Apr 8, 2014
Time of sampling	10:10 AM	10:15 AM	10:18 AM	10:22 AM	10:26 AM	10:29 AM	10:39 AM	10:42 AM
All β	ND(15)	ND(15)	ND(15)	ND(15)	ND(15)	ND(15)	ND(15)	ND(15)
H-3 (Approx. 12 years)	47	230*1	690*1	64	100	170	410	1300*1

\* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

\*1 The highest measurement value (compared to the previous values provided in the handouts published in 'Sampling Results Regarding the Influence on the Water Leak at a Tank in the H4 area in Fukushima Daiichi Nuclear Power Station (Pump Well)' in the past)

<Reference> The Highest Dose Until the Previous Measurement

	No.5	No.6	No.7	No.8
All β	ND	ND	ND	ND
H-3 (Approx. 12 years)	48 <3/25>	210 <3/25>	620 [11/19]	97 [11/26]

	No.9	No.10	No.11	No.12
All β	ND	ND	ND	ND
H-3 (Approx. 12 years)	100 [11/26,12/3]	330 [9/1,9/2]	480 [10/22,11/5]	1,200 <3/4,3/11,3/25>

Unit: Bq/L, sampling date is provided in parentheses.  
 [ ]: 2013, <>: 2014

