

## Analysis Results of Rainwater Obtained Inside the Dike at the Tank Area After Treated by the Rainwater Treatment System

### <Mobile RO membrane system>

	Measurement result [Bq/L]		Sampling place	Sampling date	Sampling time
	Chemical Analysis Building *	Laboratory at Unit 5 and 6			
Cs-134	ND ( 7.7E-01 )	ND ( 6.7E-01 )	Treated water tank	Jul 15, 2014	3:20 PM
Cs-137	ND ( 6.3E-01 )	ND ( 9.6E-01 )			
Gross β	ND ( 8.7E-01 )	1.7E+00			
Tritium	1.3E+02	ND ( 1.1E+02 )	Receiving tank	Jul 11, 2014	1:50 PM
Notification density rate*	0.051	0.080			

\* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

\* Analysis of tritium is performed at Environment Management Building.