Unit: Bq/L

	Ba	

	Seawater of the south water outlet Note (near the drainage channel exit) (T-2)	Drainage channel C OP.35 exit (C-2)	Point near the main gate in the drainage channel C Note 2 (C-0)	Point near Fureai Intersection in the drainage channel B
Date of Sampling	Apr 7, 2014	Apr 7, 2014		
Time of sampling	8:12 AM	8:01 AM		
Cs-134(Approx. 2 years)	ND(1.3)	ND(18)		
Cs-137(Approx.30 years)	ND(1.4)	ND(26)		
Gross β	ND(18)	57		

Note 2: Water inflow location of drainage channel to the tank area

<Reference> The Highest Dose Until the Previous Measurement

	Seawater of the south water outlet Note 1 (near the drainage channel exit) (T-2)	Drainage channel C OP.35 exit (C-2)	Point near the main gate in the drainage channel C Note 2 (C-0)
Cs-134(Approx. 2 years)	3.5 [11/9]	45 [9/26]	20 <2/15>
Cs-137(Approx.30 years)	8.1 [9/15,11/9]	130 [9/26]	51 <2/15>
Gross β	ND	2,500 [10/24]	120 <2/15>


Unit: Ba/L

Unit: Ba/L

			Offit. DQ/L
	Point near Fureai Intersection in the drainage channel B Note 2 (B-0-1)	Side ditch next to the tank (point immediately short of the junction with the drainage channel C) (X-1)	Side ditch next to the tank (X-2)
Cs-134(Approx. 2 years)	70 [9/4]	450 [10/4]	260 [11/10]
Cs-137(Approx.30 years)	190 (9/4)	990 [10/4]	530 [11/10]
Gross β	380 [9/2]	15,000 [10/2]	15,000 [10/14]

^{*} Sampling date is provided in parentheses. []: 2013, <>: 2014

	Side ditch next to the tank (point immediately short of the junction with the drainage channel C) (X-1)	Side ditch next to the tank (X-2)
Date of Sampling	Apr 7, 2014	Apr 7, 2014
Time of sampling	7:50 AM	7:49 AM
Cs-134(Approx. 2 years)	ND(17)	ND(15)
Cs-137(Approx.30 years)	ND(25)	30
Gross β	59	62



B-0-1 Point near Fureai Intersection in the drainage channel B

Point near the main gate in the drainage channel C

^{* &}quot;ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

^{*} The ducting is provided in the dot line.