					Unit: Bq/L
	Seawater of the south water outlet Note 1 (near the drainage channel exit) (T-2)	Drainage channel C OP.35 exit (C-2)	Switched drainage channel C OP.35 exit (C-2-1)	Point near the main gate in the drainage channel C Note 2 (C-0)	Point near Fureai Intersection in the drainage channel B Note 2 (B-0-1)
Date of Sampling	Aug 2, 2014	Aug 2, 2014	Aug 2, 2014		
Time of sampling	7:55 AM	7:41 AM	7:38 AM		
Cs-134(Approx. 2 years)	ND(1.1)	ND(14)	ND(2.3)		
Cs-137(Approx.30 years)	ND(1.2)	ND(24)	2.9		
Gross β	ND(18)	14	ND(12)		

	Unit: Bq/L	
	Side ditch next to the tank (point immediately short of the junction with the drainage channel C) (X-1)	
Date of Sampling	Aug 2, 2014	
Time of sampling	7:26 AM	
Cs-134(Approx. 2 years)	34	
Cs-137(Approx.30 years)	100	
Gross β	150	

Note 2: Water inflow location of drainage channel to the tank area


<Reference> The Highest Dose Until the Previous Measurement

Unit: Bq/L

	Seawater of the south water outlet Note 1 (near the drainage channel exit) (T-2)	Drainage channel C OP.35	Switched drainage channel C OP.35 exit (C-2-1)
Cs-134(Approx. 2 years)	3.5 [11/9]	45 [9/26]	2.9 <7/18>
Cs-137(Approx.30 years)	8.1 (9/15,11/9)	130 [9/26]	10 <7/18>
Gross β	ND	2,500 [10/24]	45 <7/18>

	Point near the main gate in the drainage channel C Note 2 (C-0)	Point near Fureai Intersection in the drainage channel B Note 2 (B-0-1)	Side ditch next to the tank (point immediately short of the junction with the drainage channel C) (X-1)
Cs-134(Approx. 2 years)	20 <2/15>	110 <5/1>	450 [10/4]
Cs-137(Approx.30 years)	51 <2/15>	280 <5/1>	990 [10/4]
Gross β	120 <2/15>	380 [9/2]	15,000 [10/2]

^{*} Sampling date is provided in parentheses. []: 2013, <>: 2014



Note 1: Approx. 330m south from Unit 1-4 water outlet (T-2)

^{* &}quot;ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.