

Sampling Results Regarding the Water Leak at the Tanks in the H4 area in Fukushima Daiichi Nuclear Power Station (South Water Outlet, Drainage Channel)

<Reference>
November 21, 2014
Tokyo Electric Power Company

	Unit: Bq/L				
	Seawater of the south water outlet <small>Note 1</small> (near the drainage channel exit) (T-2)	Drainage channel C OP.35 exit (C-2)	Switched drainage channel C OP.35 exit (C-2-1)	Point near the main gate in the drainage channel C <small>Note 2</small> (C-0)	Point near Fureai Intersection in the drainage channel B <small>Note 2</small> (B-0-1)
Date of Sampling	Nov 20, 2014	Nov 20, 2014	Nov 20, 2014	/	Nov 20, 2014
Time of sampling	7:25 AM	※	7:10 AM	/	6:50 AM
Cs-134(Approx. 2 years)	ND(1.2)	※	ND(1.9)	/	ND(17)
Cs-137(Approx.30 years)	ND(1.4)	※	ND(2.3)	/	51
Gross β	ND(18)	※	ND(15)	/	91

	Unit: Bq/L
	Side ditch next to the tank (point immediately short of the junction with the drainage channel C) (X-1)
Date of Sampling	Nov 20, 2014
Time of sampling	7:00 AM
Cs-134(Approx. 2 years)	ND(14)
Cs-137(Approx.30 years)	ND(23)
Gross β	36

Note 1: Approx. 330m south of Unit 1-4 water outlets (T-2)

Note 2: Water inflow location of drainage channel to the tank area

* "ND"s above indicate that the measurement results are below the detection limits, and the detection limit of each nuclide is provided in parentheses.

※ Sampling was not implemented since there was no water left.

<Reference> The Highest Dose Until the Previous Measurement

	Unit: Bq/L		
	Seawater of the south water outlet <small>Note 1</small> (near the drainage channel exit) (T-2)	Drainage channel C OP.35 exit (C-2)	Switched drainage channel C OP.35 exit (C-2-1)
Cs-134(Approx. 2 years)	3.5 [11/9]	45 [9/26]	5.9 <8/11>
Cs-137(Approx.30 years)	8.1 [9/15,11/9]	130 [9/26]	15 <8/11>
Gross β	ND	2,500 [10/24]	78 <9/7>

	Point near the main gate in the drainage channel C <small>Note 2</small> (C-0)	Point near Fureai Intersection in the drainage channel B <small>Note 2</small> (B-0-1)	Side ditch next to the tank (point immediately short of the junction with the drainage channel C) (X-1)
Cs-134(Approx. 2 years)	20 <2/15>	110 <5/1>	450 [10/4]
Cs-137(Approx.30 years)	51 <2/15>	280 <5/1>	990 [10/4]
Gross β	120 <2/15>	380 [9/2]	15,000 [10/2]

* Sampling dates of 2013 are provided in square brackets, [] and those of 2014 in angle brackets, < >.

