Nuclides Analysis Result of the Sub-drain Water in the Surroundings of the Central Radioactive Waste Treatment Facility

I-131(Bq/cm³)

Sampling	Mar 23 Mar 24 Mar 25 Mar 26 Mar 27 Mar 28 Mar 29 Mar 30 Mar 31 Apr 01 Apr 02 Apr 03 Apr 04 Apr 05 Apr 06																		
Location	Mar 23	Mar 24	Mar 25	Mar 26	Mar 27	Mar 28	Mar 29	Mar 30	Mar 31	Apr 01	Apr 02	Apr 03	Apr 04	Apr 05	Apr 06				
1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	*1	ND	ND	ND				
2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	*1	ND	ND	ND				
3	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	*1	ND	ND	ND				
4	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-				
⑤	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	*1	ND	ND	ND				
6	-	ND	-	-	-	-	-	-	ND	-	-	-	-	-	-				
7	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	*1	ND	ND	ND				
8	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	*1	ND	ND	ND				
9	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	*1	ND	ND	ND				

Cs-134(Bq/cm³)

Sampling																		
Location	Mar 23	Mar 24	Mar 25	Mar 26	Mar 27	Mar 28	Mar 29	Mar 30	Mar 31	Apr 01	Apr 02	Apr 03	Apr 04	Apr 05	Apr 06			
1	ND	*1	0.024	0.013	ND													
2	ND	*1	ND	ND	ND													
3	ND	*1	ND	ND	ND													
4	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
⑤	ND	*1	ND	ND	ND													
6	-	ND	-	-	-	-	-	-	ND	-	-	-	-	-	-			
7	0.038	0.028	0.023	0.038	0.034	0.03	0.036	0.027	0.027	0.021	0.02	*1	0.041	0.042	0.026			
8	ND	*1	0.045	0.028	0.046													
9	ND	*1	ND	ND	ND													

Cs-137(Bq/cm³)

Sampling																		
Location	Mar 23	Mar 24	Mar 25	Mar 26	Mar 27	Mar 28	Mar 29	Mar 30	Mar 31	Apr 01	Apr 02	Apr 03	Apr 04	Apr 05	Apr 06			
1	ND	*1	0.056	0.037	0.022													
2	ND	*1	ND	ND	ND													
3	ND	*1	ND	ND	ND													
4	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
5	ND	*1	ND	ND	ND													
6	-	ND	-	-	-	-	-	-	ND	-	-	-	-	-	-			
7	0.084	0.081	0.094	0.076	0.086	0.11	0.11	0.07	0.076	0.09	0.083	*1	0.1	0.088	0.081			
8	ND	*1	0.14	0.1	0.096													
9	ND	*1	ND	ND	ND													

- * Hyphen "-" indicates that neither sampling nor measurement was implemented.
- * 6 was selected as a sampling location in the upstream of groundwater (sampling done once a week starting from April 29, 2011) since it became unable to do sampling at 4.
- * Sampling at ⑦ (located in the downstream of the groundwater) has been done since May 26, 2011.
- * Samping at ® since May 30, 2011
- * Sampling at ⁽⁹⁾ has been done since August 2, 2011
- * "ND" indicates that the measurement result is below the detection limit.

I-131: Approx. 0.01Bq/cm³, Cs-134: Approx. 0.01Bq/cm³, Cs-137: Approx. 0.02Bq/cm³ (April 6, 2014)

As the detection limit may vary depending on the detectors and sample properties, there are cases where nuclides below the detection limit are detected.

*1 The sampling could not be performed on April 3, since a tsunami warning was issued.

- <Place of Sampling>
- 1 Southeast of Unit 4 Turbine Building
- 2 Northeast of the Process Main Building
- 3 Southeast of the Process Main Building
- Southwest of the Process Main Building
- 5 South Part of the Miscellaneous Solid Waste Volume Reduction Treatment Building
- 6 Southwest Part of the On-site Bunker Building
- West Side of the Incineration Workshop Building
- North Part of the Miscellaneous Solid Waste Volume Reduction Treatment Building
- (9) Southeast Part of the On-site Bunker Building