

## Fukushima Daiichi Nuclear Power Station: Analysis Results regarding the Discharge of Treated Water in the Subdrain and Groundwater Drain Systems

Unit: Bq/L

	North side of Unit 5 and 6 drainage opening		Port opening	
	Sept. 14, 2015	Sept. 14, 2015	Sept. 14, 2015	Sept. 14, 2015
Date	Sept. 14, 2015	Sept. 14, 2015	Sept. 14, 2015	Sept. 14, 2015
Status	Before discharging <sup>*1</sup>	During discharging	Before discharging <sup>*1</sup>	During discharging
Time	9:00	11:55	9:00	12:00
Cs-134	ND(0.70)	ND(0.46)	ND(0.66)	ND(0.60)
Cs-137	ND(0.72)	0.75	ND(0.78)	ND(0.58)
Gross β	14	7.6	18	ND(17)
Tritium	ND(1.8)	ND(1.8)	ND(1.8)	ND(1.8)

\* "ND" means not detectable. The number shown in parenthesis is the detection limit.

<sup>\*1</sup> The data represent the sampling results after the previous discharge of water from a temporary water storage tank.