

Results of Water Level Measurement at Sub-drain Pits around Central Radioactive Waste Treatment Facility  
(Oct. 1 - Oct. 31, 2013)

(Unit: mm)

Number	No.112 (Northeast of Process Main Building)		No.125 (West of Incineration Workshop Building)		No.133 (West of On- site Bunker Building)		No.150 (East of Miscellaneous Solid Waste Volume Reduction Treatment Building)		No.151 (North of Miscellaneous Solid Waste Volume Reduction Treatment Building)		No.152 (West of Miscellaneous Solid Waste Volume Reduction Treatment Building)		No.153 (South of Miscellaneous Solid Waste Volume Reduction Treatment Building)	
	Date- Month	Water level (OP+)	Depth from GL	Water level (OP+)	Depth from GL	Water level (OP+)	Depth from GL	Water level (OP+)	Depth from GL	Water level (OP+)	Depth from GL	Water level (OP+)	Depth from GL	Water level (OP+)
1-Oct	7,200	2,800	7,720	2,280	7,140	2,860	9,900	100	9,940	60	9,920	80	9,910	90
2-Oct	7,200	2,800	7,740	2,260	7,270	2,730	9,950	50	9,980	20	9,960	40	9,980	20
3-Oct	7,400	2,600	8,290	1,710	7,410	2,590	10,000	0	10,020	-20	9,990	10	10,000	0
4-Oct	7,350	2,650	8,090	1,910	7,360	2,640	9,950	50	9,990	10	9,970	30	9,970	30
5-Oct	7,350	2,650	7,990	2,010	7,380	2,620	9,950	50	9,990	10	9,970	30	9,980	20
6-Oct	7,400	2,600	8,060	1,940	7,360	2,640	9,950	50	9,990	10	9,970	30	9,970	30
7-Oct	7,400	2,600	8,100	1,900	7,370	2,630	9,950	50	10,000	0	9,980	20	9,990	10
8-Oct	7,450	2,550	8,050	1,950	7,440	2,560	9,950	50	9,990	10	9,970	30	9,990	10
9-Oct	7,450	2,550	8,010	1,990	7,390	2,610	9,950	50	9,990	10	9,970	30	9,980	20
10-Oct	7,500	2,500	7,970	2,030	7,400	2,600	9,950	50	9,980	20	9,960	40	9,980	20
11-Oct	7,500	2,500	7,950	2,050	7,400	2,600	9,950	50	9,990	10	9,970	30	9,970	30
12-Oct	7,350	2,650	7,930	2,070	7,350	2,650	9,950	50	9,980	20	9,960	40	9,970	30
13-Oct	7,350	2,650	7,890	2,110	7,330	2,670	9,900	100	9,960	40	9,940	60	9,940	60
14-Oct	7,400	2,600	7,860	2,140	7,350	2,650	9,950	50	9,940	60	9,930	70	9,950	50
15-Oct	7,400	2,600	7,860	2,140	7,310	2,690	9,950	50	9,960	40	9,940	60	9,930	70
16-Oct	7,800	2,200	8,960	1,040	7,810	2,190	10,300	-300	10,330	-330	10,360	-360	10,310	-310
17-Oct	7,650	2,350	8,680	1,320	7,720	2,280	10,000	0	10,040	-40	10,020	-20	10,000	0
18-Oct	7,650	2,350	8,440	1,560	7,580	2,420	10,000	0	10,020	-20	10,000	0	10,000	0
19-Oct	7,650	2,350	8,330	1,670	7,660	2,340	10,000	0	10,010	-10	9,990	10	10,000	0
20-Oct	7,650	2,350	8,280	1,720	7,720	2,280	10,000	0	10,010	-10	9,990	10	10,010	-10
21-Oct	7,950	2,050	9,050	950	8,000	2,000	10,000	0	10,070	-70	10,050	-50	10,050	-50
22-Oct	7,700	2,300	8,690	1,310	7,850	2,150	10,000	0	10,050	-50	10,020	-20	10,030	-30
23-Oct	7,800	2,200	8,770	1,230	7,860	2,140	10,000	0	10,060	-60	10,040	-40	10,040	-40
24-Oct	7,850	2,150	8,640	1,360	7,900	2,100	10,000	0	10,040	-40	10,020	-20	10,020	-20
25-Oct	7,850	2,150	8,590	1,410	7,900	2,100	10,000	0	10,050	-50	10,030	-30	10,030	-30
26-Oct	7,700	2,300	8,840	1,160	7,740	2,260	10,050	-50	10,090	-90	10,070	-70	10,070	-70
27-Oct	7,700	2,300	8,660	1,340	7,730	2,270	10,000	0	10,040	-40	10,020	-20	10,020	-20
28-Oct	7,700	2,300	8,450	1,550	7,700	2,300	10,000	0	10,020	-20	10,000	0	10,000	0
29-Oct	7,700	2,300	8,370	1,630	7,740	2,260	10,000	0	10,020	-20	10,000	0	10,000	0
30-Oct	7,750	2,250	8,330	1,670	7,760	2,240	10,000	0	10,020	-20	10,000	0	10,010	-10
31-Oct	7,700	2,300	8,270	1,730	7,730	2,270	10,000	0	10,020	-20	10,000	0	10,000	0

Note: GL (Ground level) of Central Radioactive Waste Treatment Facility is OP+10m.