

Result of Nuclide Analysis of Spent Fuel Pool Water of Unit 1 Fukushima
Daiichi Nuclear Power Station

June 24th, 2011
Tokyo Electric Power Company

- Sampling Date : June 22nd, 2011
- Analysis Date : June 22nd, 2011
- Result of Analysis

Nuclide Detected	[Half life]	Density (Bq/cm ³)
Cesium 134	Approx 2 years	12,000
Cesium 137	Approx 30 years	14,000
Iodine 131	Approx 8 days	68

reference : Result of Nuclide Analysis of Spent Fuel Water of Unit 1 Fukushima Daiichi
Nuclear Power Station on February 11, 2011

Nuclide Detected	[Half life]	Density (Bq/cm ³)
Cesium 134	Approx 2 years	Not Detectable
Cesium 137	Approx 30 years	0.078
Iodine 131	Approx 8 days	Not Detectable

End