

Result of Analysis of Accumulated Water Treatment

September 17, 2011
Tokyo Electric Power Company

Treatment facility	Water desalinations (R O)
--------------------	-----------------------------

	Before treatment
Sample	Water before desalinations
Date / Time	Sep 16, 2011 5:36 pm
Place	intake line of RO waste water tank

	Before treatment
Nuclide	sample density (Bq/cm ³)
I-131	ND (<1.3E+00)
Cs-134	1.2E+02
Cs-137	1.4E+02

. E- have the same meaning of . ×10⁻