

# Analysis Results: Water after RO Treatment of Accumulated Water in Unit 5/6

**【Sample】** Water after RO Treatment of Accumulated Water in Unit 5/6

**【Results】**

Unit : Bq/cm<sup>3</sup>

		<sup>131</sup> I	<sup>134</sup> Cs	<sup>137</sup> Cs	Other Nuclide	<sup>3</sup> H	All Nuclides	All Nuclides	<sup>89</sup> Sr, <sup>90</sup> Sr
Date of Measurement		10/19	10/19	10/19	10/19	10/14	10/14	10/14	9/27
Water after RO Treatment	Radioactivity Concentration	ND	ND	ND	ND	$2.6 \times 10^0$	ND	ND	ND
	Detection Limit	$8.8 \times 10^{-4}$	$1.3 \times 10^{-3}$	$1.4 \times 10^{-3}$	-	$1.0 \times 10^{-1}$	$3.2 \times 10^{-3}$	$2.1 \times 10^{-2}$	<sup>89</sup> Sr: $8.4 \times 10^{-5}$ <sup>90</sup> Sr: $4.8 \times 10^{-5}$
Standards for Bathing Area		$3.0 \times 10^{-2}$	$5.0 \times 10^{-2}$ (Total of 2 Nuclides)		/	/	/	/	/
(Reference) WHO Standards		$1.0 \times 10^{-2}$	$1.0 \times 10^{-2}$	$1.0 \times 10^{-2}$	-	$1.0 \times 10^{+1}$	$5.0 \times 10^{-4}$	$1.0 \times 10^{-3}$	<sup>89</sup> Sr: $1 \times 10^{-1}$ <sup>90</sup> Sr: $1 \times 10^{-2}$

**【Evaluation】**

The results are below the standards for bathing area.  
 Detection limit of all nuclides and all nuclides exceeds the WHO standards. However, it is assumed from the following reasons that the results are below the standards.

- Since the grain size of nuclide is large, it is assumed that it can be almost removed by RO.
- Detection limit of <sup>89</sup>Sr and <sup>90</sup>Sr that occupy the majority of all nuclides is far below the standard for all nuclides.

