

**【Reference】**

December 4, 2011  
Tokyo Electric Power Company

**Fukushima Daiichi Nuclear Power Station**  
**Sampling result of leaked water from the evaporative condensation apparatus**

**【Place of sampling】** leaked water from the evaporative condensation apparatus

**【Date of sampling】** 1:15 PM on December 4, 2011 (Sun)

**【Result】**

Nuclides	Density of radioactive substances ( Bq/cm <sup>3</sup> )	Half-time
I-131	ND	Approx 8 days
Cs-134	$1.6 \times 10^1$	Approx 2 years
Cs-137	$2.9 \times 10^1$	Approx 30 years