

**Plant Status of Fukushima Daiichi Nuclear Power Station**

December 25, 2011  
Tokyo Electric Power Company

<Draining Water on Underground Floor of Turbine Building (T/B)>

Status of highly concentrated accumulated radioactive water treatment facility and storage tank facility

[Treatment Facility]

- 6/17 20:00 Full operation of radioactive material removal instruments started.
- 6/24 12:00 Desalination facilities operation started.
- 6/27 16:20 Circulating injection cooling started.
- 8/7 16:11 Evaporative Concentration Facility has started full operation.
- 8/19 19:33 We activated 2nd cesium adsorption facility (System B) and started the treatment of accumulated water by the parallel operation of cesium adsorption instrument and decontamination instrument. At 19:41, the flow rate achieved a steady state.

[Storage Facility]

- 6/8 ~ Large tanks to store and keep treated or contaminated water have been transferred and installed sequentially.

Accumulated water in vertical shafts of trenches and at basement level of building

| Unit   | Draining water source Place transferred  | Status   |
|--------|--|--|
| Unit 1 | ·Unit 1T/B Unit 2T/B   | · 16:07 on December 23 –<br>9:38 on December 25 – Transferred. |
| Unit 2 | ·Unit 2T/B Central Radioactive Waste Treatment Facility<br>[Process Main Building, Miscellaneous Solid Waste Volume<br>Reduction Treatment Building(High Temperature Incinerator<br>Building)] | · 13:57 on December 21-<br>9:42 December 23 -Transferred       |
| Unit 3 | ·Unit 3T/B Central Radioactive Waste Treatment Facility<br>[Process Main Building, Miscellaneous Solid Waste Volume<br>Reduction Treatment Building(High Temperature Incinerator<br>Building)] | · 14:35 on December 24 -Transferring                           |
| Unit 6 | ·Unit 6T/B Temporary tanks   | · 12/25 No plan of transfer                                    |

| Place transferred   | Status of Water Level (As of December 25 at 7:00)   |
|---|---|
| Process Main Building   | Water level: O.P.+ 2,031 mm(Accumulated total increase: 3,248 mm)<br>15mm increase since 7:00 on December 24  |
| Miscellaneous Solid Waste<br>Volume Reduction Treatment<br>Building<br>(High Temperature Incinerator<br>Building) | Water level: O.P.+ 2,634 mm(Accumulated total increase: 3,360 mm)<br>503mm increase since 7:00 on December 24 |

Water level of the vertical shaft of the trench, T/B and R/B(As of December 25 at 7:00)

|        | Vertical Shaft of Trench                                   | T/B   | R/B  |
|--------|--|---|--|
| Unit 1 | O.P.< + 850 mm<br>(No change since 7:00 on<br>December 24) | O.P.+ 2,807 mm<br>(371mm decrease since 7:00 on<br>December 24) | O.P.+ 4,232 mm<br>(9mm increase since 7:00 on<br>December 24)  |
| Unit 2 | O.P.+ 3,148 mm<br>(114mm increase since 7:00 on            | O.P.+ 3,130 mm<br>(100mm increase since 7:00 on<br>December 24) | O.P.+ 3,250 mm<br>(99mm increase since 7:00 on<br>December 24) |

|        |  |  |  |
|--------|--|--|--|
|        | December 24)   |  |  |
| Unit 3 | O.P.+ 3,206 mm<br>(22mm decrease since 7:00 on<br>December 24) | O.P.+ 3,145 mm<br>(59mm decrease since 7:00 on<br>December 24) | O.P.+ 3,406 mm<br>(47mm decrease since 7:00 on<br>December 24) |
| Unit 4 | -  | O.P.+ 3,162 mm<br>(18mm decrease since 7:00 on<br>December 24) | O.P.+ 3,184 mm<br>(1mm decrease since 7:00 on<br>December 24)  |

<Monitoring of Radioactive Materials>

Nuclide Analysis of Seawater(Reference)

| Place of sampling                                   | Date of sampling | Time of sampling | Ratio of density limit (times) |        |        |
|---|------------------|------------------|--------------------------------|--------|--------|
|   |                  |                  | I-131                          | Cs-134 | Cs-137 |
| Approx. 30m North of Discharge Channel of 5,6U, 1F  | 12/24            | 8:30             | ND                             | 0.07   | 0.06   |
| Approx. 330m South of Discharge Channel of 1-4U, 1F | 12/24            | 8:10             | ND                             | 0.02   | 0.03   |
| Around Iwasawa coast, 2F (Approx. 16 km from 1F)    | 12/24            | 7:45             | ND                             | ND     | 0.01   |

·Others: samples from 1 location at the coast of Fukushima Daiichi Nuclear Power Plant (sampled on December 24) showed ND for all three major nuclides (Iodine-131, Cs-134,137).

<Cooling of Spent Fuel Pools> (As of December 25 at 11:00)

| Unit          | Cooling type               | Status of cooling | Temperature of water in Pool |
|---------------|----------------------------|-------------------|------------------------------|
| <u>Unit 1</u> | Circulating Cooling System | Under operation   | 11.0                         |
| <u>Unit 2</u> | Circulating Cooling System | Under operation   | 18.3                         |
| <u>Unit 3</u> | Circulating Cooling System | Under operation   | 12.8                         |
| <u>Unit 4</u> | Circulating Cooling System | Under operation   | 20                           |

[Unit 4] · 11/29 ~ We started operation of the ion exchange equipment to remove salt from spent fuel pool.

< Water Injection to Pressure Containment Vessels > (As of December 25 at 11:00)

| <u>Unit</u> | Status of water injection   | Feed-water nozzle Temp. | Reactor pressure vessel Bottom temp. | Pressure of primary containment vessel |
|-------------|---|-------------------------|--------------------------------------|--|
| Unit 1      | Injecting freshwater<br>(Feed Water System: Approx. 4.3 m <sup>3</sup> /h,<br>Core Spray System: Approx. 2.0m <sup>3</sup> /h)  | 28.2                    | 29.0                                 | 105.3 kPaabs                           |
| Unit 2      | Injecting freshwater<br>(Feed Water System: Approx. 2.8 m <sup>3</sup> /h,<br>Core Spray System: Approx. 6.0m <sup>3</sup> /h)  | 57.0                    | 59.9                                 | 109 kPaabs                             |
| Unit 3      | Injecting freshwater<br>(Feed Water System: Approx. 3.0 m <sup>3</sup> /h,<br>Core Spray System: Approx. 6.0 m <sup>3</sup> /h) | 51.3                    | 59.3                                 | 101.6 kPaabs                           |

[Unit 4] [Unit 5] [Unit 6] · No major change

<Others>

· 10/7 ~ Continuously implementing water spray using water after purifying accumulated water of Unit 5 and Unit 6 to prevent spontaneous fire of trimmed trees and diffusion of dust.