

Result of measurement of dose equivalent rate in Unit 2 of Fukushima Daini NPS

Atmosphere

Measured amount of atmosphere dose equivalent rate inside D/W, geometric mean for each floor

	at last periodic inspection (Mar 6, 2010)	at current outage (Mar 6, 2012)
OP38m	0.07	0.03
OP35m	0.02	0.02
OP32m	0.03	0.02
OP28m	0.27	0.21
OP21m	0.04	0.05
OP18m	0.07	0.07

