


Main works and steps for decommissioning

Fuel removal from Unit 4 SFP had been completed. Preparatory works to remove fuel from Unit 1-3 SFP and fuel debris (Note 1) removal are ongoing.

(Note 1) Fuel assemblies melted through in the accident.



Fuel removal from SFP

On December 22, 2014, all fuel removal from Unit 4 was completed.

Fuel removal from Unit 4 SFP commenced on November 18, 2013. Removal of spent fuel assemblies was completed on November 5, 2014, and removal of non-irradiated fuel assemblies was completed on December 22, 2014.



(Fuel-removal operation)

Three principles behind contaminated water countermeasures

Countermeasures for contaminated water (Note 2) are implemented in accordance with the following three principles:

(Note 2) The amount is decreasing due to measures such as groundwater bypass and water-stoppage of the buildings.

1. Eliminate contamination sources

- Multi-nuclide removal equipment, etc.
- Remove contaminated water in the trench (Note 3)


(Note 3) Underground tunnel containing pipes.

2. Isolate water from contamination

- Pump up ground water for bypassing
- Pump up ground water near buildings
- Land-side impermeable walls
- Wells near the buildings (sub-drain)
- Groundwater bypass
- Waterproof pavement

3. Prevent leakage of contaminated water

- Soil improvement by sodium silicate
- Sea-side impermeable walls
- Increase tanks (welded-joint tanks)



Multi-nuclide removal equipment (ALPS), etc.


- This equipment removes radionuclides from the contaminated water in tanks, and reduces risks.
- It aims to reduce the levels of 62 nuclides in contaminated water to the legal release limit or lower (tritium cannot be removed).
- Furthermore, contaminated water is treated by installing additional multi-nuclide removal equipment by TEPCO (operation commenced September 2014) and a subsidy project of the Japanese Government (operation commenced October 2014).



(Installation status of high-performance multi-nuclide removal equipment)

Land-side impermeable walls

- The land-side impermeable walls surround the buildings and reduce groundwater inflow into the same.
- On-site tests have been conducted since August 2013. Construction work commenced in June 2014 and the freezing operation is scheduled to start within not later than 3.31.2015.



(Length: approx. 1,500m)

Sea-side impermeable walls

- The walls aim to prevent the flow of contaminated groundwater into the sea.
- Installation of steel sheet piles is almost (98%) complete. The closure time is being coordinated.



(Installation status)

Progress status

◆ The temperatures of the Reactor Pressure Vessel (RPV) and the Primary Containment Vessel (PCV) of Units 1-3 have been maintained within the range of approx. 20-45°C¹ for the past month. There was no significant change in the density of radioactive materials newly released from Reactor Buildings in the air². It was evaluated that the comprehensive cold shutdown condition had been maintained.


¹ The values vary somewhat depending on the unit and location of the thermometer.

² The radiation exposure dose due to the current release of radioactive materials from the Reactor Buildings peaked at 0.03 mSv/year at the site boundaries. This is approx. 1/70 of the annual radiation dose by natural radiation (annual average in Japan: approx. 2.1 mSv/year).

Strontium removal operation by cesium absorption apparatuses (KURION/SARRY) commenced

The cesium absorption apparatus (KURION) and the secondary cesium absorption apparatus (SARRY) that remove cesium from contaminated water transferred from buildings were modified to make them capable of removing strontium and operation in work that commenced on December 26.

As it was confirmed that the strontium removal capability achieved the target, no additional RO concentrated salt water (contaminated water, which requires strontium treatment, stored in tanks) has been generated since January 19.



<Whole image of water treatment facilities>

Operation of RO concentrated water treatment equipment commenced


In addition to the multi-nuclide removal equipment (ALPS), multiple types of strontium removal equipment have been installed to progress with the treatment of contaminated water in tanks. New RO concentrated water treatment equipment was installed and the treatment of contaminated water commenced on January 10.

Multiple measures will continue, aiming to reduce the risks of contaminated water.

Outlook of contaminated water treatment

Regarding contaminated water treatment by multi-nuclide removal equipment (ALPS), it is estimated that treatment of the all the contaminated water would be difficult within this fiscal year at the current rate, and the work was postponed to May.

The specific completion time will be announced by mid-March.



Investigation on fuel debris inside Unit 1 reactor will commence

To investigate the existence of fuel debris in the Unit 1 reactor, measurement using muons (a type of elementary particle), which are derived from cosmic radiation will commence.

The investigative results will be utilized to assess the fuel debris removal method.


Removal of broken thermometer inside Unit 2 reactor completed for replacing

To remove the thermometer, which had broken in February 2014, rust-stripping chemicals were injected from January 14 and the broken thermometer was removed on January 19.

A new thermometer will be reinstalled within this fiscal year.

Filling of Unit 3 seawater-pipe trench tunnel sections by the grout will commence

Regarding the Unit 3 seawater-pipe trench (Note) leading from Unit 3 Turbine Building to the sea side, filling of tunnel sections will commence using a method similar to the Unit 2 seawater-pipe trench.



<Plan view of Unit 3 seawater-pipe trench>

Note: The term 'trench' means an underground tunnel containing pipes.

Fukushima Advisory Board on Decommissioning and Contaminated Water Management was held

On January 7, the 6th meeting (Fukushima City) was held to introduce the concept on the revision of the Mid-and-Long-Term Roadmap and received feedback from local municipal chief.

The roadmap will be revised based on these opinions.


Fatal accident involving worker falling from roof of tank

On January 19, an accident while a tank for receiving rainwater was being installed, where a worker who was preparing for investigation inside the tank fell from the tank roof (height: approx. 10m) and passed away the next day.

From January 21, all works onsite were suspended to conduct a safety inspection.

A detailed investigation will be conducted to clarify the cause of this incident as well as striving to prevent recurrence.

Major initiatives – Locations on site



Provided by Japan Space Imaging, (C) DigitalGlobe

* Data of Monitoring Posts (MP1-MP8.)

Data of Monitoring Posts (MPs) measuring airborne radiation rate around site boundaries show 1.053 - 3.963 μ Sv/h (December 24, 2014 – January 27, 2015).

We improved the measurement conditions of monitoring posts 2 to 8 for precise measurement of air dose rate. Construction works such as tree-clearing, surface soil removal, and shield wall setting were implemented from Feb 10 to Apr 18, 2012.


Therefore monitoring results at these points are lower than elsewhere in the power plant site.

The radiation shielding panel around the monitoring post No. 6, which is one of the instruments used to measure the radiation dose of the power station site boundary, were taken off from July 10 to July 11, 2013, since the surrounding radiation dose has largely fallen down due to further cutting down of the forests etc.

I. Confirmation of the reactor conditions

1. Temperatures inside the reactors


Through continuous reactor cooling by water injection, the temperatures of the Reactor Pressure Vessel (RPV) bottom and the Primary Containment Vessel (PCV) gas phase have been maintained within the range of approx. 10 to 40°C for the past month, though they vary depending on the unit and location of the thermometer.



* The trend graphs show part of the temperature data measured at multiple points.

2. Release of radioactive materials from the Reactor Buildings

The density of radioactive materials newly released from Reactor Building Units 1-4 in the air measured at site boundaries was evaluated at approx. 1.4×10^{-9} Bq/cm³ for both Cs-134 and -137. The radiation exposure dose due to the release of radioactive materials was 0.03 mSv/year (equivalent to approx. 1/70 of the annual radiation dose by natural radiation (annual average in Japan: approx. 2.1 mSv/year)) at the site boundaries.



Note: Different formulas and coefficients were used to evaluate the radiation dose in the facility operation plan and monthly report. The evaluation methods were integrated in September 2012. As the fuel removal from the spent fuel pool (SFP) commenced for Unit 4, the radiation exposure dose from Unit 4 was added to the items subject to evaluation since November 2013.

3. Other indices

There was no significant change in indices, including the pressure in the PCV and the PCV radioactivity density (Xe-135) for monitoring criticality, nor was any abnormality of cold shutdown condition or sign of criticality detected.

Based on the above, it was confirmed that the comprehensive cold shutdown condition had been maintained and the reactors remained in a stabilized condition.

II. Progress status by each plan

1. Reactor cooling plan

The cold shutdown condition will be maintained by cooling the reactor by water injection and measures to complement status monitoring will continue to be implemented

➤ Replacement of the thermometer at the bottom of Unit 2 RPV

- In April, attempts to remove and replace the thermometer installed at the bottom of the RPV, which had broken in February 2014, failed and the operation was suspended. The estimated cause was fixing or added friction due to rust having formed.
- Full-scale piping was used to confirm the potential for wire guides to be drawn out, contingent on the use of rust-stripping chemicals that do not generate hydrogen (December 5, 2014). Rust-stripping chemicals were injected from January 14 and the broken thermometer was removed on January 19. In the next steps, a method to install a new thermometer will be examined, the workers involved will be trained and the new thermometer will be reinstalled within this fiscal year.

2. Accumulated water-treatment plan

To tackle the increase in accumulated water due to groundwater inflow, fundamental measures to prevent such inflow into the Reactor Buildings will be implemented, while improving the decontamination capability of water-treatment and preparing facilities to control the contaminated water

➤ Operation of groundwater bypass

- From April 9, 2014, the operation of 12 groundwater bypass pumping wells commenced sequentially to pump up groundwater. The release commenced from May 21, 2014 in the presence of officials from the Intergovernmental Liaison Office for the Decommissioning and Contaminated Water Issue of the Cabinet Office. As of January 28, 73,806 m³ of groundwater had been released. The pumped up groundwater has been temporarily stored in tanks and released after TEPCO and a third-party organization (Japan Chemical Analysis Center) confirmed that its quality met operational targets.
- It was confirmed that the groundwater inflow into the buildings had decreased by 100m³/day based on the evaluation data to date through measures such as the groundwater bypass and water stoppage of the High Temperature Incinerator Building (HTI) (see Figure 1).
- It was confirmed that the groundwater level at the observation holes had decreased by approx. 10-15cm compared to the level before pumping at the groundwater bypass started.
- Due to a decrease in the flow rate of pumping well Nos. 10 and 12, water pumping was stopped for cleaning (No. 10: from January 13, No. 12: from December 12, 2014 to January 6, 2015).




Figure 1: Analytical results of inflow into buildings

➤ Construction status of land-side impermeable walls

- To facilitate the installation of land-side impermeable walls surrounding Units 1-4 (a subsidy project of the Ministry of Economy, Trade and Industry), drilling to place frozen pipes commenced (from June 2, 2014). As of January 28, drilling at 1,144 points (for frozen pipes: 940 of 1,549 points, for temperature-measurement pipes: 204 of 321 points) and installation of frozen pipes at 594 of 1,549 points had been completed (see Figure 2).




Figure 2: Drilling status for frozen-soil impermeable walls and installation of frozen pipes





Figure 3: Whole image of water treatment facilities

➤ Operation of multi-nuclide removal equipment

- Regarding multi-nuclide removal equipment (existing, additional and high-performance), hot tests using radioactive water are underway (for existing equipment, System A: from March 30, 2013, System B: from June 13, 2013, System C: from September 27, 2013; for additional equipment, System A: from September 17, 2014, System B: from September 27, 2014, System C: from October 9, 2014; for high-performance equipment, from October 18, 2014). To date, approx. 196,000 m³ at the existing, approx. 64,000 m³ at the additional and approx. 18,000 m³ at the high-performance multi-nuclide removal equipment have been treated (as of January 22, including approx. 9,500m³ stored in J1(D) tank, which contained water with a high density of radioactive materials at the System B outlet).

➤ Toward reducing the risk of contaminated water stored in tanks

- Operation at RO concentrated water treatment equipment that removes strontium from RO concentrated salt water commenced (January 10). As of January 22, approx. 8,000 m³ had been treated.
- To purify the RO concentrated salt water stored in tanks, mobile strontium-removal equipment is being operated in the G4 south area (G4 south area: from October 2, 2014). As of January 22, approx. 4,000 m³ of contaminated water had been treated. As of January 22, approx. 4,000 m³ of contaminated water is being treated.
- Treatment measures comprising the removal of strontium by cesium absorption apparatus (KURION) and secondary cesium absorption apparatus (SARRY) commenced (from January 6, 2015 and December 26, 2014). The decreased strontium concentration in treated water was confirmed (January 19), whereupon stored water in tanks after treatment was handled as strontium treated water. No additional RO concentrated salt water was generated. As of January 22, approx. 1,000 m³ has been treated.



* Since January 1, 2015, data collection days have been changed (from Tuesdays to Thursdays)

Figure 4: Status of accumulated water storage

➤ Outlook of contaminated water treatment

- Regarding the treatment of contaminated water by multi-nuclide removal equipment, it is considered difficult to treat the entire volume of contaminated water within this fiscal year at the current rate and the work was postponed to May.
- The specific completion time will be announced by mid-March.

➤ Measures in Tank Areas

- Rainwater under the temporary release standard having accumulated inside the fences in the contaminated water tank area, was sprinkled on site after removing radioactive materials using rainwater-treatment equipment since May 21, 2014 (as of January 26, a total of 13,820 m³).

➤ Removal of contaminated water from seawater-pipe trenches

- Regarding the Unit 2 seawater-pipe trench, filling of the tunnel sections was completed on December 18, 2014. Water was pumped up from the Vertical Shafts on December 24, 2014 and January 20, 2015 and the filling status of the tunnel sections was confirmed. Filling of the Vertical Shafts will proceed after confirming the stoppage status.
- Regarding the Unit 3 seawater-pipe trench, filling of the tunnel sections will commence.
- Regarding the Unit 4 seawater-pipe trench, inside filling will be done after disconnecting the building from the trench to prevent the filler flowing into the Turbine Building side.




Figure 5: Sectional view of the Unit 4 seawater-pipe trench

3. Plan to reduce radiation dose and mitigate contamination

Effective dose-reduction at site boundaries and purification of the port water to mitigate the impact of radiation on the external environment

➤ Status of groundwater and seawater on the east side of Turbine Building Units 1 to 4

- Regarding the radioactive materials in groundwater near the bank on the north side of the Unit 1 intake, tritium densities have been increasing at groundwater Observation Holes Nos. 0-1-2 and 0-4 since July 2014 and currently stand at around 10,000 and 23,000 Bq/L respectively in these locations. Pumping of 1 m³/day of water from Observation Hole No. 0-3-2 continues.
- Regarding the groundwater near the bank between the Unit 1 and 2 intakes, the density of gross β radioactive materials at groundwater Observation Hole No. 1-6 increased to 7.8 million Bq/L in October 2014, but currently stands at around 500,000 Bq/L. Though the density of tritium at groundwater Observation Hole No. 1-8 had become around 10,000 Bq/L, it fluctuated greatly after June 2014 and is currently around 30,000 Bq/L. Though the tritium at groundwater Observation Hole No. 1-17, which had been around 10,000 Bq/L, increased to 160,000 Bq/L since October 2014, it currently stands at around 40,000 Bq/L. The density of gross β, which has been increasing since March 2014, reached 1.2 million Bq/L by October and currently stands at around 200,000 Bq/L. Water pumping from the well point (10m³/day) and the pumping well No. 1-16 (P) (1m³/day) installed near the Observation Hole No. 1-16 continues.
- Regarding the radioactive materials in groundwater near the bank between the Unit 2 and 3 intakes, the densities of tritium and gross β radioactive materials have been decreasing since November 2014, currently standing at around 3,000 and 40,000 Bq/L for tritium and gross β radioactive materials respectively. To increase the height of the ground improvement area with mortar, the volume of water pumped from the well point increased to 50 m³/day (from October 31, 2014). The height increase commenced on January 8.
- Regarding the radioactive materials in groundwater near the bank between the Unit 3 and 4 intakes, a low density was maintained at all Observation Holes as up to December 2014.
- Regarding the radioactive materials in seawater outside the seaside impermeable walls and within the open channels of Units 1-4, a low density equivalent to that at the point north of the east breakwater was maintained as up to December 2014.
- The density of radioactive materials in seawater within the port has been slowly declining as up to December 2014.
- The radioactive material density in seawater at outside the port entrance has remained within the same range previously recorded.
- Construction to cover the seabed soil within the port is underway to prevent contamination spreading due to

stirred-up seabed soil (scheduled for completion at the end of FY2014). Since December 14, 2014, Area (2) is being covered. As of January 27, 44% of the construction had been completed (see Figure 9). The seabed of the intake open channels had been covered by FY2012.

- Curtain nets with cesium and strontium absorption fibers attached were installed at the opening of the seaside impermeable walls (January 15).




Figure 6: Groundwater density on the Turbine Building east side

- Main work to help remove spent fuel at Unit 1
 - Spraying of anti-scattering agents on the top floor of the Reactor Building and investigations into the status of rubble and concentration of dust were conducted and the roof panels of the Reactor Building cover that had been removed were replaced on December 4, 2014.
 - After March, dismantling of the building cover is scheduled to progress by once again removing the roof panel.

5. Fuel debris removal plan

In addition to decontamination and shield installation to improve PCV accessibility, technology was developed and data gathered as required to prepare to remove fuel debris (such as investigating and repairing PCV leak locations)

- Development of technology to detect fuel debris inside the reactor
 - To gain insight into the positions and amounts of fuel debris, as required to examine fuel debris removal methods, there are plans to measure the position of debris via imaging technology using muons (a type of elementary particle), which are derived from cosmic radiation. A detector will be installed to the northwest outside the Unit 1 Reactor Building and measurement using muon radiography is scheduled to commence.
- Decontamination of the Unit 3 Reactor Building 1st floor
 - Prior to future investigation inside the PCV, a radiation-source survey was conducted on Unit 3 Reactor Building 1st floor up to December. Since January 5, middle-place decontamination has been underway using dedicated equipment.

6. Plan to store, process and dispose of solid waste and decommission reactor facilities

Promoting efforts to reduce and store waste generated appropriately and R&D to facilitate adequate and safe storage, processing and disposal of radioactive waste

- Management status of rubble and trimmed trees
 - As of the end of December 2014, the total storage volume of concrete and metal rubble was approx. 134,400 m³ (+2,500 m³ compared to at the end of November 2014, area-occupation rate: 56%). The total storage volume of trimmed trees was approx. 79,700 m³ (±0 m³ compared to at the end of November 2014, area-occupation rate: 58%). The increase in rubble was mainly attributable to construction to install tanks.
- Management status of secondary waste from water treatment
 - As of January 22, the total storage volume of waste sludge was 597 m³ (area-occupation rate: 85%) and concentrated waste fluid was 8,948 m³ (area-occupation rate: 45%). The total number of stored spent vessels and high-integrity containers (HICs) for multi-nuclide removal equipment was 1,621 (area-occupation rate: 49%).

7. Plan for staffing and ensuring work safety

Securing appropriate staff long-term while thoroughly implementing workers' exposure dose control. Improving the work environment and labor conditions continuously based on an understanding of workers' on-site needs

- Staff management
 - The monthly average total of people registered for at least one day per month to work on site during the past quarter from September to November 2014 was approx. 13,900 (TEPCO and partner company workers), which exceeded the monthly average number of actual workers (approx. 11,000). Accordingly, sufficient people are registered to work on site.
 - It was confirmed with the prime contractors that the estimated manpower necessary for the work in February (approx. 6,770 per day: TEPCO and partner company workers)* would be secured at present. The average numbers of workers per day for each month of the last fiscal year (actual values) were maintained with approx. 3,000 to 6,900 per month since the last fiscal year (See Figure 11).

* Some works for which contractual procedures have yet to be completed are excluded from the February estimate.

- The number of workers is increasing, both from within and outside Fukushima prefecture. However, as the growth rate of workers from outside exceeds that of those from within the prefecture, the local employment ratio (TEPCO and partner company workers) as of December was approx. 45%.




Figure 11: Changes in the average number of workers per weekday for each month since FY2013

- The average exposure dose of workers remained at approx. 1mSv/month during both FY2013 and FY2014. (Reference: annual average exposure dose 20mSv/year ≈ 1.7mSv/month)
- For most workers, the exposure dose is sufficiently within the limit and at a level which allows them to continue engaging in radiation work.




Figure 12: Changes in monthly individual worker exposure dose (monthly average exposure dose since March 2011)

- Preventing infection and expansion of influenza and norovirus
 - Since October 2014, measures for influenza and norovirus have been implemented. As part of these efforts, free influenza vaccination (subsidized by TEPCO) is being provided at the new Administration Office Building in the Fukushima Daiichi Nuclear Power Station (from October 29 to December 5, 2014) and medical clinics around the site (from November 4, 2014 to January 30, 2015) for partner company workers. As of January 27, 2015, a total of 8,445 workers had been vaccinated. In addition, a comprehensive range of other measures is also being implemented, including daily actions to prevent infection and expansion (measuring body temperature, health checks and monitoring infection status) and response after detecting possible infections (control of swift entry/exit and mandatory wearing of masks in working spaces).
- Status of influenza and norovirus cases
 - From the 47th week of 2014 (November 10-17, 2014) to the 4th week of 2015 (January 19-25, 2015), there were 279 cases of influenza infection and 5 case of norovirus infection. The totals for the same period of the previous season showed 39 cases of influenza infection and 25 cases of norovirus infection. The totals for the entire previous season (December 2013 to May 2014) were 254 cases of influenza infection and 35 cases of norovirus infection.

➤ Progress of the new Administration Office Building

- To facilitate efforts to closely collaborate with surrounding buildings, expedite operations and use the premises more effectively, the building location changed.
- The process was reviewed due to the numerous works involved in removing and transferring obstacles.
- Construction will commence in June 2015 and be completed in August 2016.

8. Others

➤ Fukushima Advisory Board on Decommissioning and Contaminated Water Management (6th meeting) was held

- On January 7, the 6th meeting (Fukushima City) was held to introduce the concept of revising the Mid-and-Long-Term Roadmap and feedback from local residents was received. The roadmap will be revised based on these opinions.


➤ Fatal accident involving a worker falling from the roof of a rainwater receiving tank

- On January 19, an accident occurred while a tank for receiving rainwater was being installed, whereby a worker who was preparing for an investigation inside the tank after the water filling test fell from the tank roof (height: approx. 10m) and passed away the next day.
- From January 21, all works onsite were suspended to conduct a safety inspection.
- A detailed investigation will be conducted to clarify the cause of this incident as well as striving to prevent recurrence.

Status of seawater monitoring within the port (comparison between the highest values in 2013 and the latest values)

“The highest value” → “the latest value (sampled during January 19-26)”; unit (Bq/L); ND represents a value below the detection limit

Source: TEPCO website Analysis results on nuclides of radioactive materials around Fukushima Daiichi Nuclear Power Station <http://www.tepco.co.jp/nu/fukushima-np/f1/smp/index-j.html>



Cesium-134: 3.3 (2013/10/17) → ND(1.1) Below 1/3
Cesium-137: 9.0 (2013/10/17) → ND(1.2) Below 1/7
Gross β: **74** (2013/ 8/19) → ND(16) Below 1/4
Tritium: 67 (2013/ 8/19) → 5.4 Below 1/10

Cesium-134: 4.4 (2013/12/24) → ND(1.3) Below 1/3
Cesium-137: 10 (2013/12/24) → 1.2 Below 1/8
Gross β: **60** (2013/ 7/ 4) → ND(16) Below 1/3
Tritium: 59 (2013/ 8/19) → 6.7 Below 1/8

Cesium-134: 5.0 (2013/12/2) → ND(1.0) Below 1/5
Cesium-137: 8.4 (2013/12/2) → ND(1.3) Below 1/6
Gross β: **69** (2013/8/19) → 16 Below 1/4
Tritium: 52 (2013/8/19) → 5.1 Below 1/10

Cesium-134: 2.8 (2013/12/2) → ND(2.0) Below 1/2
Cesium-137: 5.8 (2013/12/2) → ND(2.1) Below 1/2
Gross β: **46** (2013/8/19) → ND(18) Below 1/2
Tritium: 24 (2013/8/19) → ND(3.1) Below 1/7

Cesium-134: ND(1.6)
Cesium-137: 4.3
Gross β: **36**
Tritium: 61
(Sampled on January 19)

Cesium-134: 3.3 (2013/12/24) → ND(1.2) Below 1/2
Cesium-137: 7.3 (2013/10/11) → ND(1.3) Below 1/5
Gross β: **69** (2013/ 8/19) → ND(16) Below 1/4
Tritium: 68 (2013/ 8/19) → 2.7 Below 1/20

Cesium-134: 3.5 (2013/10/17) → ND(1.3) Below 1/2
Cesium-137: 7.8 (2013/10/17) → ND(1.2) Below 1/6
Gross β: **79** (2013/ 8/19) → ND(16) Below 1/4
Tritium: 60 (2013/ 8/19) → 8.6 Below 1/6

Cesium-134: 32 (2013/10/11) → ND(2.3) Below 1/10
Cesium-137: 73 (2013/10/11) → 7.2 Below 1/10
Gross β: **320** (2013/ 8/12) → **40** Below 1/8
Tritium: 510 (2013/ 9/ 2) → 460

Cesium-134: ND(2.2)
Cesium-137: 6.7
Gross β: **49**
Tritium: 360 *

Cesium-134: ND(2.2)
Cesium-137: 4.8
Gross β: **53**
Tritium: 340 *


Cesium-134: 2.0
Cesium-137: 5.9
Gross β: **53**
Tritium: 240 *

Cesium-134: **62** (2013/ 9/16) → 3.4 Below 1/9
Cesium-137: **140** (2013/ 9/16) → **12** Below 1/5
Gross β: **360** (2013/ 8/12) → **60** Below 1/3
Tritium: 400 (2013/ 8/12) → 660

Cesium-134: 5.3 (2013/8/ 5) → ND(1.2) Below 1/3
Cesium-137: 8.6 (2013/8/ 5) → ND(1.9) Below 1/4
Gross β: **40** (2013/7/ 3) → ND(18) Below 1/2
Tritium: 340 (2013/6/26) → 3.3 Below 1/100

Cesium-134: **28** (2013/ 9/16) → 2.4 Below 1/10
Cesium-137: **53** (2013/12/16) → 9.1 Below 1/5
Gross β: **390** (2013/ 8/12) → **49** Below 1/7
Tritium: 650 (2013/ 8/12) → 700

Note: The gross β measurement values include natural potassium 40 (approx. 12 Bq/L).



	Legal discharge limit	WHO Guidelines for Drinking Water Quality
Cesium-134	60	10
Cesium-137	90	10
Strontium-90 (strongly correlate with Gross β)	30	10
Tritium	60,000	10,000

Summary of TEPCO data of January 28

Status of seawater monitoring around outside of the port (comparison between the highest values in 2013 and the latest values)

(The latest values sampled during January 19-26)

Unit (Bq/L); ND represents a value below the detection limit; values in () represent the detection limit; ND (2013) represents ND throughout 2013

	Legal discharge limit	WHO Guidelines for Drinking Water Quality
Cesium-134	60	10
Cesium-137	90	10
Strontium-90 (strongly correlate with Gross β)	30	10
Tritium	60,000	10,000

【Northeast side of port entrance(offshore 1km)】

Cesium-134: ND (2013) → ND (0.70)
 Cesium-137: ND (2013) → ND (0.74)
 Gross β: ND (2013) → ND (15)
 Tritium: ND (2013) → ND (1.5)

【East side of port entrance (offshore 1km)】

Cesium-134: ND (2013) → ND (0.76)
 Cesium-137: 1.6 (2013/10/18) → ND (0.67) Below 1/2
 Gross β: ND (2013) → ND (15)
 Tritium: 6.4 (2013/10/18) → ND (1.5) Below 1/4

【Southeast side of port entrance(offshore 1km)】

Cesium-134: ND (2013) → ND (0.87)
 Cesium-137: ND (2013) → ND (0.78)
 Gross β: ND (2013) → ND (15)
 Tritium: ND (2013) → ND (1.5)

Cesium-134: ND (2013) → ND (0.44)
 Cesium-137: ND (2013) → ND (0.70)
 Gross β: ND (2013) → ND (15)
 Tritium: 4.7 (2013/ 8/18) → ND (1.5) Below 1/3

【South side of south breakwater(offshore 0.5km)】

Cesium-134: ND (2013) → ND (0.77)
 Cesium-137: ND (2013) → ND (0.65)
 Gross β: ND (2013) → ND (15)
 Tritium: ND (2013) → ND (1.5)

【North side of north breakwater(offshore 0.5km)】

Cesium-134: 1.8 (2013/ 6/21) → ND (0.73) Below 1/3
 Cesium-137: 4.5 (2013/ 3/17) → ND (0.75) Below 1/6
 Gross β: **12** (2013/12/23) → **15**
 Tritium: 8.6 (2013/ 6/26) → ND (1.6) Below 1/2




【Port entrance】

Cesium-134: 3.3 (2013/12/24) → ND (1.2) Below 1/2
 Cesium-137: 7.3 (2013/10/11) → ND (1.3) Below 1/5
 Gross β: **69** (2013/ 8/19) → ND (16) Below 1/4
 Tritium: 68 (2013/ 8/19) → 2.7 Below 1/20

Cesium-134: ND (2013) → ND (0.79)
 Cesium-137: 3.0 (2013/ 7/15) → ND (0.60) Below 1/5
 Gross β: **15** (2013/12/23) → **13**
 Tritium: 1.9 (2013/11/25) → ND (1.6)

Note: The gross β measurement values include natural potassium 40 (approx. 12 Bq/L).


Summary of TEPCO data as of January 28



Source: TEPCO website, Analysis results on nuclides of radioactive materials around Fukushima Daiichi Nuclear Power Station, <http://www.tepco.co.jp/nu/fukushima-np/f1/smp/index-j.html>



Status of efforts on various plans (Part 1)

As of January 29, 2015



Status of efforts on various plans (Part 2)

As of January 29, 2015




Objective: Establish decontamination robot technology

Status of efforts on various plans (Part 3)


As of January 29, 2015

→ : Main processes
→ : Sub-main processes
 : Field work
 : R&D
 : Review
 : Plan until last month
 : Green frame: Change from last month



Status of efforts on various plans (Part 4)

As of January 29, 2015



HP ND-1

Establishment of decommissioning scenarios

Progress toward decommissioning: Fuel removal from the spent fuel pool (SFP)


Immediate target Commence fuel removal from the Unit 1-3 Spent Fuel Pools

Unit 4

In the Mid- and Long-Term Roadmap, the target of Phase 1 involved commencing fuel removal from inside the spent fuel pool (SFP) of the 1st Unit within two years of completion of Step 2 (by December 2013). On November 18, 2013, fuel removal from Unit 4, or the 1st Unit, commenced and Phase 2 of the roadmap started.

On November 5, 2014, within a year of commencing work to remove the fuel, all 1,331 spent fuel assemblies in the pool had been transferred.
The transfer of the remaining non-irradiated fuel assemblies to the Unit 6 SFP was completed on December 22, 2014.
(2 of the non-irradiated fuel assemblies were removed in advance in July 2012 for fuel checks) This marks the completion of fuel removal from the Unit 4 Reactor Building.


Based on this experience, fuel assemblies will be removed from Unit 1-3 pools.




Fuel removal status

Conditions in the Unit 4 SFP


Work is proceeding with appropriate risk countermeasures, careful checks and safety first



Check of the soundness of the Reactor Building
Since May 2012, regular quarterly inspections have been conducted, which have confirmed that the soundness of the Reactor Building has been maintained.



Check for tilt (measurement of the water level)



Check for tilt (measurement of the external wall)

Unit 3

To facilitate the installation of a cover for fuel removal, installation of the gantry was completed (March 13, 2013). Removal of rubble from the roof of the Reactor Building was completed (October 11, 2013). Currently, toward the installation of a cover for fuel removal and the fuel-handling machine on the operating floor (*1), measures to reduce the radiation dose (decontamination and shielding) are underway (from October 15, 2013). Removal of large rubble from the SFP is also underway (from December 17, 2013).



Before removal of the large rubble

After removal of the large rubble




Image of the cover for fuel removal

Units 1 and 2


- Regarding Unit 1, to remove rubble from the top of the operating floor, there are plans to dismantle the cover over the Reactor Building. Two roof panels of the Unit 1 Reactor Building (R/B) were removed to facilitate investigation of the rubble status on the R/B top floor. No scattering of dust or conditions that would cause immediate damage to the fuel assemblies in the SFP were detected.
- Regarding Unit 2, to prevent risks of reworking due to change in the fuel debris removal plan, the plan continues to be examined within a scope not affecting the scheduled commencement of removal.

Dismantling of the cover over Reactor Building Unit 1

To facilitate the early removal of fuel and fuel debris from the SFP, the cover over the Reactor Building will be dismantled to accelerate the removal of rubble on the operation floor. The radiation dose on the site boundaries will also increase compared to before the dismantling. However, through measures to reduce the release, the estimated impact of the release from Units 1 to 3 on the site boundaries (0.03mSv/year) will be limited.




Common pool



An open space will be maintained in the common pool (Transfer to the temporary dry cask storage facility)

- Progress to date
- The common pool has been restored to a condition allowing it to re-accommodate fuel to be handled (November 2012)
 - Loading of spent fuel stored in the common pool to dry casks commenced (June 2013)
 - Fuel removed from the Unit 4 spent fuel pool began to be received (November 2013)



Operation commenced on April 12, 2013; from the cask-storage building, transfer of 9 existing dry casks completed (May 21, 2013); fuel stored in the common pool sequentially transferred.

<Glossary>
(*1) Operating floor: During regular inspection, the roof over the reactor is opened while on the operating floor, fuel inside the core is replaced and the core internals are inspected.
(*2) Cask: Transportation container for samples and equipment, including radioactive materials.

* Some portions of these photos, in which classified information related to physical protection is included, were corrected.


Immediate target	Identify the plant status and commence R&D and decontamination toward fuel debris removal
-------------------------	--

3D laser scan inside the Unit 1 R/B underground floor

The upper part of the underground floor (torus room) of Unit 1 R/B was investigated with a laser scan using a remote-controlled robot, and collected 3D data.


3D data, which allows examination based on actual measurements, can be used to examine more detailed accessibility and allocation of equipment.

Combining it with 3D data on the R/B 1st floor allows obstacles on both 1st and underground floors to be checked simultaneously. This allows efficient examination of positions to install repair equipment for PCVs and vacuum break lines.




Investigation in the leak point detected in the upper part of Unit 1 Suppression Chamber (S/C^(*))

Investigation in the leak point detected in the upper part of Unit 1 S/C from May 27, 2014 from one expansion joint cover among the lines installed there. As no leakage was identified from other parts, specific methods will be examined to halt the flow of water and repair the PCV.



Unit 1



* Indices related to the plant are values as of 11:00, January 28, 2015 Turbine Building

Status of equipment development toward investigating inside the PCV


Prior to removing fuel debris, to check the conditions inside the Primary Containment Vessel (PCV), including the location of the fuel debris, investigation inside the PCV is scheduled.

[Investigative outline]

- Inserting equipment from Unit 1 X-100B penetration⁽⁵⁾ to investigate in clockwise and counter-clockwise directions.

[Status of investigation equipment development]

- Crawler-type equipment with a shape-changing structure which allows it to enter the PCV from the narrow access entrance (bore: φ100mm) and stably move on the grating is currently under development. A field demonstration is scheduled for the 1st half of FY2015.




Investigative route inside the PCV (draft plan)

- <Glossary>
- (*) S/C (Suppression Chamber): Suppression pool, used as the water source for the emergent core cooling system.
 - (*) SFP (Spent Fuel Pool):
 - (*) RPV (Reactor Pressure Vessel)
 - (*) PCV (Primary Containment Vessel)
 - (*) Penetration: Through-hole of the PCV

Immediate target Identify the plant status and commence R&D and decontamination toward fuel debris removal

Installation of an RPV thermometer and permanent PCV supervisory instrumentation



- (1) Replacement of the RPV thermometer
 - As the thermometer installed at the Unit 2 RPV bottom after the earthquake had broken, it was excluded from the monitoring thermometers (February 19, 2014).
 - On April 17, 2014, removal of the broken thermometer failed and was suspended. Rust-stripping chemicals were injected and the broken thermometer was removed on January 19, 2015.
 - A new thermometer will be reinstalled within this fiscal year.
- (2) Reinstallation of the PCV thermometer and water-level gauge
 - Some of the permanent supervisory instrumentation for PCV could not be installed in the planned locations due to interference with existing grating (August 13, 2013).
 - The instrumentation was removed on May 27, 2014 and new instruments were reinstalled on June 5 and 6, 2014. The trend of added instrumentation will be monitored for approx. one month to evaluate its validity.
 - The measurement during the installation confirmed that the water level inside the PCV was approx. 300mm from the bottom.



Removal situation of broken thermometer inside Unit 2 RPV

Investigative results on torus room walls

- The torus room walls were investigated (on the north side of the east-side walls) using equipment specially developed for that purpose (a swimming robot and a floor traveling robot).
- At the east-side wall pipe penetrations (five points), "the status" and "existence of flow" were checked.
- A demonstration using the above two types of underwater wall investigative equipment showed how the equipment could check the status of penetration.
- Regarding Penetrations 1 - 5, the results of checking the sprayed tracer (*) by camera showed no flow around the penetrations. (investigation by the swimming robot)
- Regarding Penetration 3, a sonar check showed no flow around the penetrations. (investigation by the floor traveling robot)



* Indices related to plant are values as of 11:00, January 28, 2015

Status of equipment development toward investigating inside the PCV


Prior to removing fuel debris, to check the conditions inside the Primary Containment Vessel (PCV), including the location of the fuel debris, investigations inside the PCV are scheduled.

[Investigative outline]

- Inserting the equipment from Unit 2 X-6 penetration^(*) and accessing inside the pedestal using the CRD rail to conduct investigation.

[Status of investigative equipment development]

- Based on issues confirmed by the CRD rail status investigation conducted in August 2013, the investigation method and equipment design are currently being examined. A demonstration is scheduled in the field in the 1st half of FY2015.



Investigative issues inside the PCV and equipment configuration (draft plan)

<Glossary>

- (*) Penetration: Through-hole of the PCV
- (2) SFP (Spent Fuel Pool)
- (3) RPV (Reactor Pressure Vessel)
- (4) PCV (Primary Containment Vessel)
- (5) Tracer: Material used to trace the fluid flow. Clay particles

Progress toward decommissioning: Works to identify the plant status and toward fuel debris removal

January 29, 2015

Secretariat of the Team for Countermeasures for Decommissioning and Contaminated Water Treatment

4/6

Immediate target


Identify the plant status and commence R&D and decontamination toward fuel debris removal

Water flow was detected from the Main Steam Isolation Valve* room

On January 18, 2014, a flow of water from around the door of the Steam Isolation Valve room in the Reactor Building Unit 3 1st floor northeast area to the nearby floor drain funnel (drain outlet) was detected. As the drain outlet connects with the underground part of the Reactor Building, there is no possibility of outflow from the building.

From April 23, 2014, image data has been acquired by camera and the radiation dose measured via pipes for measurement instrumentation, which connect the air-conditioning room on the Reactor Building 2nd floor with the Main Steam Isolation Valve Room on the 1st floor. On May 15, 2014, water flow from the expansion joint of one Main Steam Line was detected.

This is the first leak from PCV detected in Unit 3. Based on the images collected in this investigation, the leak volume will be estimated and the need for additional investigations will be examined. The investigative results will also be utilized to examine water stoppage and PCV repair methods.



* Main Steam Isolation Valve: A valve to shut off the steam generated from the Reactor in an emergency


Decontamination inside R/B

- The contamination status inside the Reactor Building (R/B) was investigated by a robot (June 11-15, 2012).
- To select an optimal decontamination method, decontamination samples were collected (June 29 to July 3, 2012).
- To facilitate decontamination inside the Reactor Building, removal of obstacles on the 1st floor was conducted (from November 18, 2013 to March 20, 2014).



Robot for investigating the contamination status (gamma camera mounted)

Unit 3




* Indices related to plant are values as of 11:00, November 26, 2014

Status of equipment development toward investigating inside the PCV

Prior to removing fuel debris, to check the conditions inside the Primary Containment Vessel (PCV), including the location of the fuel debris, investigation inside the PCV is scheduled. As the water level inside the PCV is high and the penetration scheduled for use in Units 1 and 2 may be under the water, another method needs to be examined.

[Steps for investigation and equipment development]

- (1) Investigation from X-53 penetration^(*)
 - From October 22-24, the status of X-53 penetration, which may be under the water and which is scheduled for use to investigate the inside of the PCV, was investigated using remote-controlled ultrasonic test equipment. Results showed that the penetration is not under the water.
 - An investigation of the inside of the PCV is scheduled for around the 1st half of FY2015. Given the high radioactivity around X-53 penetration, the introduction of remote-controlled equipment will be examined based on the decontamination status and shielding.
- (2) Investigation plan following the investigation of X-53 penetration
 - Based on the measurement values of hydraulic head pressure inside the PCV, X-6 penetration may decline. It is estimated that access to X-6 penetration is difficult.
 - For access from another penetration, approaches such as "further downsizing the equipment" or "moving in water to access the pedestal" are necessary and will be examined.



<Glossary>



- (*) SFP (Spent Fuel Pool)
- (*) RPV (Reactor Pressure Vessel)
- (*) PCV (Primary Containment Vessel)
- (*) Penetration: Through-hole of the PCV

Progress toward decommissioning: Work related to circulation cooling and accumulated water treatment line

Immediate target **Stably continue reactor cooling and accumulated water treatment, and improve reliability**

Work to improve the reliability of the circulation water injection cooling system and pipes to transfer accumulated water.

- Operation of the reactor water injection system using Unit 3 CST as a water source commenced (from July 5, 2013). Compared to the previous systems, in addition to the shortened outdoor line, the reliability of the reactor water injection system was enhanced, e.g. by increasing the amount of water-source storage and enhancing durability.
- By newly installing RO equipment inside the Reactor Building by the 1st half of 2015, the reactor water injection loop (circulation loop) will be shortened from approx. 3km to approx. 0.8km*.
- * The entire length of contaminated water transfer pipes is approx. 2.1km, including the transfer line of surplus water to the upper heights (approx. 1.3km).



*1 Unit 4 T/B operation floor is one of the installation proposals, which will be determined after further examination based on the work environment
 *2 A detailed line configuration will be determined after further examination

Typhoon measures improved for Tank Area

- Enhanced rainwater measures were implemented, including increasing the height of fences to increase the capacity to receive rainwater and installing rain gutters and fence cover to prevent rainwater inflow. Though a total of 300mm of rainfall was recorded by typhoon Nos. 18 and 19, no outflow of contaminated rainwater from inside the fences was detected.




Before installing the fence cover

After installing the fence cover

Toward treatment of all contaminated water


Regarding contaminated water treatment by multi-nuclide removal equipment (ALPS), etc. it is difficult to reach the initially anticipated performance due to technical reason. It is estimated that treatment of the entire amount of contaminated water would be in May 2015. Specific time of the completion will be announced by mid-March.

Efforts will continue to improve treatment capability aiming to reduce risks as soon as possible.



Preventing water from accessing contamination source

Preventing groundwater from flowing into the Reactor Buildings




Aiming to reduce the level of groundwater by pumping subdrain water, tests were conducted to verify the stable operation of water treatment facilities, including subdrain. The results showed that through purification by the system, the density of radioactive materials declined to below the operational target and no other γ nuclides were detected.

Reducing groundwater inflow by pumping sub-drain water

Measures to pump up groundwater flowing from the mountain side upstream of the Building to reduce the groundwater inflow (groundwater bypass) have been implemented. The pumped up groundwater is temporarily stored in tanks and released after TEPCO and a third-party organization have confirmed that its quality meets operational targets. Through periodical monitoring, pumping of wells and tanks is operated appropriately. At the observation holes installed at a height equivalent to the buildings, the trend showing a decline in groundwater levels is checked. The analytical results on groundwater inflow into the buildings based on existing data showed a declining trend.

Via a groundwater bypass, reduce the groundwater level around the Building and groundwater inflow into the Building



To prevent the inflow of groundwater into the Reactor Buildings, installation of impermeable walls surrounding the buildings on the land side is planned. Targeting efforts to commence freezing at the end of FY2014, drilling holes to install frozen pipes commenced from June 2, 2014.

<Glossary>
 (*1) CST (Condensate Storage Tank)
 Tank for temporarily storing water used in the plant.

Installing land-side impermeable walls around Units 1-4 to prevent the inflow of groundwater into R/B

Progress toward decommissioning: Work to improve the environment within the site

<p>Immediate targets</p>	<ul style="list-style-type: none"> Reduce the effect of additional release from the entire power station and radiation from radioactive waste (secondary water treatment waste, rubble, etc.) generated after the accident, to limit the effective radiation dose to below 1mSv/year at the site boundaries. Prevent contamination expansion in sea, decontamination within the site
---------------------------------	--

Expansion of full-face mask unnecessary area

Operation based on the rules for mask wearing according to radioactive material density in air and decontamination/ ionization rules was defined, and the area is being expanded.

In the J tank installation area on the south side of the site, as decontamination was completed, the area will be set as full-face mask unnecessary area (from May 30, 2014), where for works not handling contaminated water, wearing disposable dust-protective masks will be deemed sufficient.




Full-face mask unnecessary area

Expansion of work areas for women

Regarding female workers engaging in radioactivity-related jobs at the Fukushima Daiichi Nuclear Power Station, there has been no onsite work area since the East Japan Great Earthquake due to the increased radioactivity rate. However, improved work environment conditions mean female workers have been allowed to work within limited onsite areas since June 2014.

Based on the improved onsite work environment and the reduced potential for internal exposure, work areas for female workers will be expanded site-wide, excluding specified high-dose works and those for which the radiation dose exceeds 4mSv per exposure (from November 4, 2014.)



Installation of impermeable walls on the sea side

To prevent contamination expansion into the sea where contaminated water had leaked into groundwater, impermeable walls are being installed (scheduled for completion in September 2014).

Installation of steel pipe sheet piles temporarily completed by December 4, 2013 except for 9 pipes.

The next stage will involve installing steel pipe sheet piles outside the port, landfilling within the port, and installing a pumping facility to close before the construction completion.



Installation status of impermeable walls on the sea side (Landfill status on the Unit 1 intake side)

Reducing radioactive materials in seawater within the harbor

- The analytical result for data such as the density and level of groundwater on the east (sea) side of the Building identified that contaminated groundwater was leaking into seawater.
- No significant change has been detected in seawater within the harbor for the past month, nor was any significant change detected in offshore measurement results as of last month.
- To prevent contamination expansion into the sea, the following measures are being implemented:
 - Prevent leakage of contaminated water
 - Ground improvement behind the bank to prevent the expansion of radioactive materials. (Between Units 1 and 2: completed on August 9, 2013; between Units 2 and 3: from August 29 and completed on December 12, 2013; between Units 3 and 4: from August 23, 2013 and completed on January 23, 2014)
 - Pumping groundwater in contaminated areas (from August 9, 2013, scheduled to commence sequentially)
 - Isolate water from contamination
 - Enclosure by ground improvement on the mountain side (Between Units 1 and 2: from August 13, 2013 and completed on March 25, 2014; between Units 2 and 3: from October 1, 2013 and completed on February 6, 2014; between Units 3 and 4: from October 19, 2013 and completed on March 5, 2014)
 - To prevent the ingress of rainwater, the ground surface was paved with concrete (commenced on November 25, 2013 and completed on May 2, 2014)
 - Eliminate contamination sources
 - Removing contaminated water in branch trenches and closing them (completed on September 19, 2013)
 - Treatment and removal of contaminated water in the seawater pipe trench
 - Unit 2: November 25 to December 18, 2014 - filling of tunnel sections with cement-based materials
 - Unit 3: Filling of tunnel sections will commence.
 - Drilling of holes to install frozen/ temperature-measurement pipes is underway.

Overview of measures

