

Situation of water level, transfer and treatment of the accumulated water in Fukushima Daiichi Nuclear Power Station (at 9:00 on December 26)

		Unit 1	Unit 2	Unit 3	Unit 4
Water Level of the accumulated water※ (at 7:00 on December 26)	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,205 mm (32 mm increase since 16:00 on December 25)	O.P.+ 3,168 mm (24 mm decrease since 16:00 on December 25)	—
	Water level of Turbine Building	O.P.+ 2,789 mm (16 mm increase since 16:00 on December 25)	O.P.+ 3,185 mm (30 mm increase since 16:00 on December 25)	O.P.+ 3,084 mm (37 mm decrease since 16:00 on December 25)	O.P.+ 3,134 mm (20 mm decrease since 16:00 on December 25)
	Water level of Reactor Building	O.P.+ 4,244 mm (6 mm increase since 16:00 on December 25)	O.P.+ 3,306 mm (30 mm increase since 16:00 on December 25)	O.P.+ 3,342 mm (39 mm decrease since 16:00 on December 25)	O.P.+ 3,152 mm (20 mm decrease since 16:00 on December 25)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 2,153 mm (Increase from initial level:3,370 mm, 117 mm increase since 16:00 on December 25) O.P.+ 3,575 mm (Increase from initial level:4,301 mm, 609 mm increase since 16:00 on December 25) O.P.+ 4,477 mm (Water level from floor:681 mm, 6 mm increase since 16:00 on December 25)		
Situation of transfer of the accumulated water		—	— Transfer suspended	Basement of Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building / High Temperature Incinerator Building) Currently being transferred (Since 14:35 on December 24)	—
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 8:58 on December 20・・・Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 8:44 on December 12・・・Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.