

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on December 26)**

		Unit 1	Unit 2	Unit 3	Unit 4
Water Level of the accumulated water (at 16:00 on December 26)	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,201 mm (4 mm decrease since 7:00 on December 26)	O.P.+ 3,161 mm (7 mm decrease since 7:00 on December 26)	—
	Water level of Turbine Building	O.P.+ 2,800 mm (11 mm increase since 7:00 on December 26)	O.P.+ 3,180 mm (5 mm decrease since 7:00 on December 26)	O.P.+ 3,107 mm (23 mm increase since 7:00 on December 26)	O.P.+ 3,122 mm (12 mm decrease since 7:00 on December 26)
	Water level of Reactor Building	O.P.+ 4,247 mm (3 mm increase since 7:00 on December 26)	O.P.+ 3,309 mm (3 mm increase since 7:00 on December 26)	O.P.+ 3,352 mm (10 mm increase since 7:00 on December 26)	O.P.+ 3,138 mm (14 mm decrease since 7:00 on December 26)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 2,082 mm (Increase from initial level:3,299 mm, 29 mm increase since 7:00 on December 26) O.P.+ 3,745 mm (Increase from initial level:4,471 mm, 170 mm increase since 7:00 on December 26) O.P.+ 4,481 mm (Water level from floor:685 mm, 4 mm increase since 7:00 on December 26)		
Situation of transfer of the accumulated water		—	Basement of Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building / High Temperature Incinerator Building) Currently being transferred (Since 10:10 on December 26)	Basement of Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building / High Temperature Incinerator Building) Transfer suspended (From 14:35 on December 24 to 9:50 on December 26)	—
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 8:58 on December 20 ... Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 8:44 on December 12 ... Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	* We mistakenly announced that the water level of Centralized Radiation Waste Treatment Facility (Process Main Building) as of 7:00 on December 26 was O.P. 2153 mm, but it has turned out that the correct number is O.P. 2053 mm.				

For quick publication of the data of water level, values are provided as reference values.