

Situation of water level, transfer and treatment of the accumulated water in Fukushima Daiichi Nuclear Power Station (at 9:00 on December 27)

		Unit 1	Unit 2	Unit 3	Unit 4
Water Level of the accumulated water (at 7:00 on December 27)	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,184 mm (17 mm decrease since 16:00 on December 26)	O.P.+ 3,169 mm (8 mm increase since 16:00 on December 26)	—
	Water level of Turbine Building	O.P.+ 2,814 mm (14 mm increase since 16:00 on December 26)	O.P.+ 3,161 mm (19 mm decrease since 16:00 on December 26)	O.P.+ 3,136 mm (29 mm increase since 16:00 on December 26)	O.P.+ 3,124 mm (2 mm increase since 16:00 on December 26)
	Water level of Reactor Building	O.P.+ 4,244 mm (3 mm decrease since 16:00 on December 26)	O.P.+ 3,291 mm (18 mm decrease since 16:00 on December 26)	O.P.+ 3,387 mm (35 mm increase since 16:00 on December 26)	O.P.+ 3,134 mm (4 mm decrease since 16:00 on December 26)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 2,153 mm (Increase from initial level:3,370 mm, 71 mm increase since 16:00 on December 26) O.P.+ 3,918 mm (Increase from initial level:4,644 mm, 173 mm increase since 16:00 on December 26) O.P.+ 4,487 mm (Water level from floor:691 mm, 6 mm increase since 16:00 on December 26)		
Situation of transfer of the accumulated water		—	Basement of Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building / High Temperature Incinerator Building) Currently being transferred (Since 10:10 on December 26)	— Transfer suspended	—
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 8:58 on December 20・・・Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 8:44 on December 12・・・Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.