

Situation of water level, transfer and treatment of the accumulated water in Fukushima Daiichi Nuclear Power Station (at 18:00 on December 27)

		Unit 1	Unit 2	Unit 3	Unit 4
Water Level of the accumulated water (at 16:00 on December 27)	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,199 mm (15 mm increase since 7:00 on December 27)	O.P.+ 3,177 mm (8 mm increase since 7:00 on December 27)	—
	Water level of Turbine Building	O.P.+ 2,823 mm (9 mm increase since 7:00 on December 27)	O.P.+ 3,176 mm (15 mm increase since 7:00 on December 27)	O.P.+ 3,145 mm (9 mm increase since 7:00 on December 27)	O.P.+ 3,125 mm (1 mm increase since 7:00 on December 27)
	Water level of Reactor Building	O.P.+ 4,243 mm (1 mm decrease since 7:00 on December 27)	O.P.+ 3,298 mm (7 mm increase since 7:00 on December 27)	O.P.+ 3,397 mm (10 mm increase since 7:00 on December 27)	O.P.+ 3,139 mm (5 mm increase since 7:00 on December 27)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 2,218 mm (Increase from initial level:3,435 mm, 65 mm increase since 7:00 on December 27) O.P.+ 3,644 mm (Increase from initial level:4,370 mm, 274 mm decrease since 7:00 on December 27) O.P.+ 4,310 mm (Water level from floor:514 mm, 177 mm decrease since 7:00 on December 27)		
Situation of transfer of the accumulated water		—	Basement of Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building / High Temperature Incinerator Building) Transfer suspended (From 10:10 on December 26 to 9:54 on December 27)	— Transfer suspended	—
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 8:58 on December 20 ∙ ∙ ∙ Suspended 2nd Cesium Adsorption Apparatus (Sarry): From 10:37 on December 27 to 18:00 on December 27 ∙ ∙ ∙ Operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.