

Situation of water level, transfer and treatment of the accumulated water in Fukushima Daiichi Nuclear Power Station (at 18:00 on December 28)

		Unit 1	Unit 2	Unit 3	Unit 4
Water Level of the accumulated water※ (at 16:00 on December 28)	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,252 mm (16 mm increase since 7:00 on December 28)	O.P.+ 3,193 mm (5 mm increase since 7:00 on December 28)	—
	Water level of Turbine Building	O.P.+ 2,845 mm (9 mm increase since 7:00 on December 28)	O.P.+ 3,223 mm (14 mm increase since 7:00 on December 28)	O.P.+ 3,163 mm (5 mm increase since 7:00 on December 28)	O.P.+ 3,139 mm (13 mm increase since 7:00 on December 28)
	Water level of Reactor Building	O.P.+ 4,245 mm (2 mm increase since 7:00 on December 28)	O.P.+ 3,351 mm (20 mm increase since 7:00 on December 28)	O.P.+ 3,417 mm (6 mm increase since 7:00 on December 28)	O.P.+ 3,154 mm (6 mm increase since 7:00 on December 28)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 2,239 mm (Increase from initial level:3,456 mm, 11 mm increase since 7:00 on December 28) O.P.+ 2,969 mm (Increase from initial level:3,695 mm, 231 mm decrease since 7:00 on December 28) O.P.+ 4,318 mm (Water level from floor:522 mm, 3 mm increase since 7:00 on December 28)		
Situation of transfer of the accumulated water		—	Basement of Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building / High Temperature Incinerator Building) Currently being transferred (Since 15:22 on December 28)	Basement of Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building / High Temperature Incinerator Building) Currently being transferred (Since 15:32 on December 28)	—
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 8:58 on December 20・・・Suspended 2nd Cesium Adsorption Apparatus (Sarry): From 10:43 on December 27 to 0:00 on January 0・・・Operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	・In "Situation of water level, transfer and treatment of the accumulated water in Fukushima Daiichi Nuclear Power Station (at 9:00 on December 28)", we stated the date and time of startup for 2nd Cesium absorption facility as "10:37 on December 27". The correct time was "10:43 on December 27". Apologies for the inconvenience caused.				

※ For quick publication of the data of water level, values are provided as reference values.