

Situation of water level, transfer and treatment of the accumulated water in Fukushima Daiichi Nuclear Power Station (at 9:00 on December 30)

		Unit 1	Unit 2	Unit 3	Unit 4
Water Level of the accumulated water (at 7:00 on December 30)	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,184 mm (12 mm increase since 16:00 on December 29)	O.P.+ 3,178 mm (12 mm increase since 16:00 on December 29)	—
	Water level of Turbine Building	O.P.+ 2,881 mm (14 mm increase since 16:00 on December 29)	O.P.+ 3,161 mm (12 mm increase since 16:00 on December 29)	O.P.+ 3,147 mm (23 mm increase since 16:00 on December 29)	O.P.+ 3,130 mm (8 mm increase since 16:00 on December 29)
	Water level of Reactor Building	O.P.+ 4,247 mm (No change since 16:00 on December 29)	O.P.+ 3,291 mm (11 mm increase since 16:00 on December 29)	O.P.+ 3,402 mm (25 mm increase since 16:00 on December 29)	O.P.+ 3,140 mm (1 mm increase since 16:00 on December 29)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 2,467 mm (Increase from initial level:3,684 mm, 20 mm increase since 16:00 on December 29) O.P.+ 3,055 mm (Increase from initial level:3,781 mm, 242 mm decrease since 16:00 on December 29) O.P.+ 4,332 mm (Water level from floor:536 mm, 4 mm increase since 16:00 on December 29)		
Situation of transfer of the accumulated water		—	Basement of Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building / High Temperature Incinerator Building) Currently being transferred (Since 15:22 on December 28)	Basement of Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building / High Temperature Incinerator Building) Transfer suspended (Since 9:03 on December 29)	—
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 8:58 on December 20 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 10:43 on December 27 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.