

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 18:00 on December 30)**

		Unit 1	Unit 2	Unit 3	Unit 4
Water Level of the accumulated water (at 16:00 on December 30)	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,178 mm (6 mm decrease since 7:00 on December 30)	O.P.+ 3,183 mm (5 mm increase since 7:00 on December 30)	—
	Water level of Turbine Building	O.P.+ 2,890 mm (9 mm increase since 7:00 on December 30)	O.P.+ 3,155 mm (6 mm decrease since 7:00 on December 30)	O.P.+ 3,149 mm (2 mm increase since 7:00 on December 30)	O.P.+ 3,131 mm (1 mm increase since 7:00 on December 30)
	Water level of Reactor Building	O.P.+ 4,248 mm (1 mm increase since 7:00 on December 30)	O.P.+ 3,293 mm (2 mm increase since 7:00 on December 30)	O.P.+ 3,410 mm (8 mm increase since 7:00 on December 30)	O.P.+ 3,144 mm (4 mm increase since 7:00 on December 30)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 2,486 mm (Increase from initial level:3,703 mm, 19 mm increase since 7:00 on December 30) O.P.+ 3,001 mm (Increase from initial level:3,727 mm, 54 mm decrease since 7:00 on December 30) O.P.+ 4,336 mm (Water level from floor:540 mm, 4 mm increase since 7:00 on December 30)		
Situation of transfer of the accumulated water		—	Basement of Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building / High Temperature Incinerator Building)  Currently being transferred (Since 15:22 on December 28)	Basement of Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building / High Temperature Incinerator Building)  Currently being transferred (Since 14:37 on December 30)	—
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 8:58 on December 20   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 10:43 on December 27   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.