

Situation of water level, transfer and treatment of the accumulated water in Fukushima Daiichi Nuclear Power Station (at 9:00 on December 31)

		Unit 1	Unit 2	Unit 3	Unit 4
Water Level of the accumulated water (at 7:00 on December 31)	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,160 mm (18 mm decrease since 16:00 on December 30)	O.P.+ 3,171 mm (12 mm decrease since 16:00 on December 30)	—
	Water level of Turbine Building	O.P.+ 2,902 mm (12 mm increase since 16:00 on December 30)	O.P.+ 3,138 mm (17 mm decrease since 16:00 on December 30)	O.P.+ 3,130 mm (19 mm decrease since 16:00 on December 30)	O.P.+ 3,137 mm (6 mm increase since 16:00 on December 30)
	Water level of Reactor Building	O.P.+ 4,246 mm (2 mm decrease since 16:00 on December 30)	O.P.+ 3,276 mm (17 mm decrease since 16:00 on December 30)	O.P.+ 3,393 mm (17 mm decrease since 16:00 on December 30)	O.P.+ 3,144 mm (No change since 16:00 on December 30)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 2,528 mm (Increase from initial level:3,745 mm, 42 mm increase since 16:00 on December 30) O.P.+ 3,236 mm (Increase from initial level:3,962 mm, 235 mm increase since 16:00 on December 30) O.P.+ 4,341 mm (Water level from floor:545 mm, 5 mm increase since 16:00 on December 30)		
Situation of transfer of the accumulated water		—	Basement of Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building / High Temperature Incinerator Building) Currently being transferred (Since 15:22 on December 28)	Basement of Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building / High Temperature Incinerator Building) Currently being transferred (Since 14:37 on December 30)	—
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 8:58 on December 20 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 10:43 on December 27 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.