

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 18:00 on December 31)**

		Unit 1	Unit 2	Unit 3	Unit 4
Water Level of the accumulated water (at 16:00 on December 31)	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,149 mm (11 mm decrease since 7:00 on December 31)	O.P.+ 3,175 mm (4 mm increase since 7:00 on December 31)	—
	Water level of Turbine Building	O.P.+ 2,910 mm (8 mm increase since 7:00 on December 31)	O.P.+ 3,128 mm (10 mm decrease since 7:00 on December 31)	O.P.+ 3,141 mm (11 mm increase since 7:00 on December 31)	O.P.+ 3,125 mm (12 mm decrease since 7:00 on December 31)
	Water level of Reactor Building	O.P.+ 4,244 mm (2 mm decrease since 7:00 on December 31)	O.P.+ 3,268 mm (8 mm decrease since 7:00 on December 31)	O.P.+ 3,397 mm (4 mm increase since 7:00 on December 31)	O.P.+ 3,141 mm (3 mm decrease since 7:00 on December 31)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 2,555 mm (Increase from initial level:3,772 mm, 27 mm increase since 7:00 on December 31) O.P.+ 3,240 mm (Increase from initial level:3,966 mm, 4 mm increase since 7:00 on December 31) O.P.+ 4,343 mm (Water level from floor:547 mm, 2 mm increase since 7:00 on December 31)		
Situation of transfer of the accumulated water		—	Basement of Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building / High Temperature Incinerator Building)  Currently being transferred (Since 15:22 on December 28)	Basement of Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building / High Temperature Incinerator Building)  Transfer suspended	—
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 8:58 on December 20   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 10:43 on December 27   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.