

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on January 1)**

		Unit 1	Unit 2	Unit 3	Unit 4
Water Level of the accumulated water (at 7:00 on January 1)	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,132 mm (17 mm decrease since 16:00 on December 31)	O.P.+ 3,188 mm (13 mm increase since 16:00 on December 31)	—
	Water level of Turbine Building	O.P.+ 2,925 mm (15 mm increase since 16:00 on December 31)	O.P.+ 3,112 mm (16 mm decrease since 16:00 on December 31)	O.P.+ 3,157 mm (16 mm increase since 16:00 on December 31)	O.P.+ 3,132 mm (7 mm increase since 16:00 on December 31)
	Water level of Reactor Building	O.P.+ 4,241 mm (3 mm decrease since 16:00 on December 31)	O.P.+ 3,254 mm (14 mm decrease since 16:00 on December 31)	O.P.+ 3,417 mm (20 mm increase since 16:00 on December 31)	O.P.+ 3,147 mm (6 mm increase since 16:00 on December 31)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 2,604 mm (Increase from initial level:3,821 mm, 49 mm increase since 16:00 on December 31) O.P.+ 3,137 mm (Increase from initial level:3,863 mm, 103 mm decrease since 16:00 on December 31) O.P.+ 4,351 mm (Water level from floor:555 mm, 8 mm increase since 16:00 on December 31)		
Situation of transfer of the accumulated water		—	Basement of Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building / High Temperature Incinerator Building) Currently being transferred (Since 15:22 on December 28)	Basement of Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building / High Temperature Incinerator Building) Transfer suspended	—
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 8:58 on December 20 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 10:43 on December 27 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.