

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on January 2)**

		Unit 1	Unit 2	Unit 3	Unit 4
Water Level of the accumulated water (at 7:00 on January 2)	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,113 mm (11 mm decrease since 16:00 on January 1)	O.P.+ 3,205 mm (12 mm increase since 16:00 on January 1)	—
	Water level of Turbine Building	O.P.+ 2,948 mm (16 mm increase since 16:00 on January 1)	O.P.+ 3,094 mm (10 mm decrease since 16:00 on January 1)	O.P.+ 3,176 mm (12 mm increase since 16:00 on January 1)	O.P.+ 3,150 mm (13 mm increase since 16:00 on January 1)
	Water level of Reactor Building	O.P.+ 4,239 mm (2 mm decrease since 16:00 on January 1)	O.P.+ 3,228 mm (13 mm decrease since 16:00 on January 1)	O.P.+ 3,437 mm (12 mm increase since 16:00 on January 1)	O.P.+ 3,165 mm (12 mm increase since 16:00 on January 1)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 2,695 mm (Increase from initial level:3,912 mm, 60 mm increase since 16:00 on January 1) O.P.+ 2,995 mm (Increase from initial level:3,721 mm, 86 mm decrease since 16:00 on January 1) O.P.+ 4,365 mm (Water level from floor:569 mm, 9 mm increase since 16:00 on January 1)		
Situation of transfer of the accumulated water		—	Basement of Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building / High Temperature Incinerator Building) Currently being transferred (Since 15:22 on December 28)	Basement of Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building / High Temperature Incinerator Building) Transfer suspended	—
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 8:58 on December 20 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 10:43 on December 27 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.