

Situation of water level, transfer and treatment of the accumulated water in Fukushima Daiichi Nuclear Power Station (at 18:00 on January 2)

		Unit 1	Unit 2	Unit 3	Unit 4
Water Level of the accumulated water (at 16:00 on January 2)	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,106 mm (7 mm decrease since 7:00 on January 2)	O.P.+ 3,211 mm (6 mm increase since 7:00 on January 2)	—
	Water level of Turbine Building	O.P.+ 2,957 mm (9 mm increase since 7:00 on January 2)	O.P.+ 3,088 mm (6 mm decrease since 7:00 on January 2)	O.P.+ 3,183 mm (7 mm increase since 7:00 on January 2)	O.P.+ 3,161 mm (11 mm increase since 7:00 on January 2)
	Water level of Reactor Building	O.P.+ 4,242 mm (3 mm increase since 7:00 on January 2)	O.P.+ 3,223 mm (5 mm decrease since 7:00 on January 2)	O.P.+ 3,445 mm (8 mm increase since 7:00 on January 2)	O.P.+ 3,172 mm (7 mm increase since 7:00 on January 2)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 2,733 mm (Increase from initial level:3,950 mm, 38 mm increase since 7:00 on January 2) O.P.+ 2,949 mm (Increase from initial level:3,675 mm, 46 mm decrease since 7:00 on January 2) O.P.+ 4,370 mm (Water level from floor:574 mm, 5 mm increase since 7:00 on January 2)		
Situation of transfer of the accumulated water		—	Basement of Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building / High Temperature Incinerator Building) Currently being transferred (Since 15:22 on December 28)	Basement of Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building / High Temperature Incinerator Building) Transfer suspended	—
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 8:58 on December 20 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 10:43 on December 27 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.