

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on January 3)**

		Unit 1	Unit 2	Unit 3	Unit 4
Water Level of the accumulated water (at 7:00 on January 3)	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,092 mm (14 mm decrease since 16:00 on January 2)	O.P.+ 3,224 mm (13 mm increase since 16:00 on January 2)	—
	Water level of Turbine Building	O.P.+ 2,974 mm (17 mm increase since 16:00 on January 2)	O.P.+ 3,074 mm (14 mm decrease since 16:00 on January 2)	O.P.+ 3,196 mm (13 mm increase since 16:00 on January 2)	O.P.+ 3,176 mm (15 mm increase since 16:00 on January 2)
	Water level of Reactor Building	O.P.+ 4,242 mm (No change since 16:00 on January 2)	O.P.+ 3,213 mm (10 mm decrease since 16:00 on January 2)	O.P.+ 3,459 mm (14 mm increase since 16:00 on January 2)	O.P.+ 3,184 mm (12 mm increase since 16:00 on January 2)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 2,795 mm (Increase from initial level:4,012 mm, 62 mm increase since 16:00 on January 2) O.P.+ 2,887 mm (Increase from initial level:3,613 mm, 62 mm decrease since 16:00 on January 2) Site bunker water level is not available due to malfunction of instrumentation equipments.		
Situation of transfer of the accumulated water		—	Basement of Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building / High Temperature Incinerator Building) Currently being transferred (Since 15:22 on December 28)	Basement of Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building / High Temperature Incinerator Building) Transfer suspended	—
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 8:58 on December 20 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 10:43 on December 27 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	Today, January 3's site bunker water level is not available due to malfunction of instrumentation equipments. We are planning to resume measurement from tomorrow, January 4.				

For quick publication of the data of water level, values are provided as reference values.