

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on January 3)**

		Unit 1	Unit 2	Unit 3	Unit 4
Water Level of the accumulated water (at 16:00 on January 3)	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,112 mm (20 mm increase since 7:00 on January 3)	O.P.+ 3,223 mm (1 mm decrease since 7:00 on January 3)	—
	Water level of Turbine Building	O.P.+ 2,983 mm (9 mm increase since 7:00 on January 3)	O.P.+ 3,092 mm (18 mm increase since 7:00 on January 3)	O.P.+ 3,186 mm (10 mm decrease since 7:00 on January 3)	O.P.+ 3,175 mm (1 mm decrease since 7:00 on January 3)
	Water level of Reactor Building	O.P.+ 4,242 mm (No change since 7:00 on January 3)	O.P.+ 3,222 mm (9 mm increase since 7:00 on January 3)	O.P.+ 3,456 mm (3 mm decrease since 7:00 on January 3)	O.P.+ 3,174 mm (10 mm decrease since 7:00 on January 3)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 2,812 mm (Increase from initial level:4,029 mm, 17 mm increase since 7:00 on January 3) O.P.+ 2,895 mm (Increase from initial level:3,621 mm, 8 mm increase since 7:00 on January 3) O.P.+ 4,384 mm (Water level from floor:588 mm, 14 mm increase since 16:00 on January 2)		
Situation of transfer of the accumulated water		—	Basement of Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building / High Temperature Incinerator Building) Transfer suspended (From 15:22 on December 28 to 9:44 on January 3)	Basement of Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building / High Temperature Incinerator Building) Currently being transferred (Since 10:01 on January 3)	—
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 8:58 on December 20 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 10:43 on December 27 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.