

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on January 4)**

| | | Unit 1 | Unit 2 | Unit 3 | Unit 4 |
|--|---|---|--|---|--|
| Water Level of the accumulated water (at 7:00 on January 4) | Water level of Vertical Shaft | Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm) | O.P.+ 3,158 mm (46 mm increase since 16:00 on January 3) | O.P.+ 3,214 mm (9 mm decrease since 16:00 on January 3) | — |
| | Water level of Turbine Building | O.P.+ 2,999 mm (16 mm increase since 16:00 on January 3) | O.P.+ 3,134 mm (42 mm increase since 16:00 on January 3) | O.P.+ 3,171 mm (15 mm decrease since 16:00 on January 3) | O.P.+ 3,171 mm (4 mm decrease since 16:00 on January 3) |
| | Water level of Reactor Building | O.P.+ 4,243 mm (1 mm increase since 16:00 on January 3) | O.P.+ 3,264 mm (42 mm increase since 16:00 on January 3) | O.P.+ 3,441 mm (15 mm decrease since 16:00 on January 3) | O.P.+ 3,170 mm (4 mm decrease since 16:00 on January 3) |
| | Water level of each building in the Centralized Radiation Waste Treatment Facility | Process Main Building High Temperature Incinerator Building On-site Bunker Building | O.P.+ 2,825 mm (Increase from initial level:4,042 mm, 13 mm increase since 16:00 on January 3) O.P.+ 2,983 mm (Increase from initial level:3,709 mm, 88 mm increase since 16:00 on January 3) O.P.+ 4,392 mm (Water level from floor:596 mm, 8 mm increase since 16:00 on January 3) | | |
| Situation of transfer of the accumulated water | | — | Transfer suspended | Basement of Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building / High Temperature Incinerator Building) Currently being transferred (Since 10:01 on January 3) | — |
| Operation condition of water treatment facility | | Cesium Adsorption Apparatus: Since 8:58 on December 20 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 10:43 on December 27 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance | | | |
| Notes | At 7 pm on January 3, site bunker water level was not available due to malfunction of instrumentation equipments. Then we restarted the equipments and they were resumed. | | | | |

For quick publication of the data of water level, values are provided as reference values.