

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on January 4)**

		Unit 1	Unit 2	Unit 3	Unit 4
Water Level of the accumulated water (at 16:00 on January 4)	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,184 mm (26 mm increase since 7:00 on January 4)	O.P.+ 3,209 mm (5 mm decrease since 7:00 on January 4)	—
	Water level of Turbine Building	O.P.+ 3,009 mm (10 mm increase since 7:00 on January 4)	O.P.+ 3,158 mm (24 mm increase since 7:00 on January 4)	O.P.+ 3,164 mm (7 mm decrease since 7:00 on January 4)	O.P.+ 3,166 mm (5 mm decrease since 7:00 on January 4)
	Water level of Reactor Building	O.P.+ 4,247 mm (4 mm increase since 7:00 on January 4)	O.P.+ 3,288 mm (24 mm increase since 7:00 on January 4)	O.P.+ 3,434 mm (7 mm decrease since 7:00 on January 4)	O.P.+ 3,180 mm (10 mm increase since 7:00 on January 4)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 2,833 mm (Increase from initial level:4,050 mm, 8 mm increase since 7:00 on January 4) O.P.+ 3,191 mm (Increase from initial level:3,917 mm, 208 mm increase since 7:00 on January 4) O.P.+ 4,397 mm (Water level from floor:601 mm, 5 mm increase since 7:00 on January 4)		
Situation of transfer of the accumulated water		—	Transfer suspended	Basement of Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building / High Temperature Incinerator Building) Currently being transferred (Since 10:01 on January 3)	—
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 8:58 on December 20 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 14:48 on January 4 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	* At 9:13 am on January 4, due to the increasing of the pump discharge pressure and the increasing of the differential pressure of the filtrate filter (filtering out oil and etc.), we stopped the 2nd Cesium Adsorption Apparatus (Sarry) and cleaned up the filtrate filter. At 2:36 pm on the same day, we restarted to operate the 2nd Cesium Adsorption Apparatus and confirmed that the flow rate had steadied at 2:48 pm.				

For quick publication of the data of water level, values are provided as reference values.