

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on January 5)**

		Unit 1	Unit 2	Unit 3	Unit 4
Water Level of the accumulated water (at 7:00 on January 5)	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,226 mm (42 mm increase since 16:00 on January 4)	O.P.+ 3,201 mm (8 mm decrease since 16:00 on January 4)	—
	Water level of Turbine Building	O.P.+ 3,024 mm (15 mm increase since 16:00 on January 4)	O.P.+ 3,196 mm (38 mm increase since 16:00 on January 4)	O.P.+ 3,154 mm (10 mm decrease since 16:00 on January 4)	O.P.+ 3,151 mm (15 mm decrease since 16:00 on January 4)
	Water level of Reactor Building	O.P.+ 4,250 mm (3 mm increase since 16:00 on January 4)	O.P.+ 3,323 mm (35 mm increase since 16:00 on January 4)	O.P.+ 3,422 mm (12 mm decrease since 16:00 on January 4)	O.P.+ 3,172 mm (8 mm decrease since 16:00 on January 4)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 2,845 mm (Increase from initial level:4,062 mm, 12 mm increase since 16:00 on January 4) O.P.+ 3,084 mm (Increase from initial level:3,810 mm, 107 mm decrease since 16:00 on January 4) O.P.+ 4,405 mm (Water level from floor:609 mm, 8 mm increase since 16:00 on January 4)		
Situation of transfer of the accumulated water		—	Transfer suspended	Basement of Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building / High Temperature Incinerator Building) Currently being transferred (Since 10:01 on January 3)	—
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 8:58 on December 20 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 14:48 on January 4 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.