

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on January 6)**

		Unit 1	Unit 2	Unit 3	Unit 4
Water Level of the accumulated water (at 7:00 on January 6)	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,203 mm (19 mm decrease since 16:00 on January 5)	O.P.+ 3,187 mm (9 mm decrease since 16:00 on January 5)	—
	Water level of Turbine Building	O.P.+ 3,044 mm (12 mm increase since 16:00 on January 5)	O.P.+ 3,175 mm (17 mm decrease since 16:00 on January 5)	O.P.+ 3,138 mm (10 mm decrease since 16:00 on January 5)	O.P.+ 3,145 mm (7 mm decrease since 16:00 on January 5)
	Water level of Reactor Building	O.P.+ 4,245 mm (4 mm decrease since 16:00 on January 5)	O.P.+ 3,313 mm (16 mm decrease since 16:00 on January 5)	O.P.+ 3,406 mm (11 mm decrease since 16:00 on January 5)	O.P.+ 3,158 mm (8 mm decrease since 16:00 on January 5)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 2,939 mm (Increase from initial level:4,156 mm, 63 mm increase since 16:00 on January 5) O.P.+ 3,225 mm (Increase from initial level:3,951 mm, 115 mm increase since 16:00 on January 5) O.P.+ 4,420 mm (Water level from floor:624 mm, 9 mm increase since 16:00 on January 5)		
Situation of transfer of the accumulated water		—	Basement of Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building / High Temperature Incinerator Building) Currently being transferred (Since 9:30 on January 5)	Basement of Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building / High Temperature Incinerator Building) Currently being transferred (Since 10:01 on January 3)	—
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 8:58 on December 20 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 14:48 on January 4 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.