

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on January 7)**

		Unit 1	Unit 2	Unit 3	Unit 4
Water Level of the accumulated water (at 7:00 on January 7)	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,180 mm (14 mm decrease since 16:00 on January 6)	O.P.+ 3,176 mm (7 mm decrease since 16:00 on January 6)	—
	Water level of Turbine Building	O.P.+ 3,064 mm (13 mm increase since 16:00 on January 6)	O.P.+ 3,153 mm (14 mm decrease since 16:00 on January 6)	O.P.+ 3,125 mm (6 mm decrease since 16:00 on January 6)	O.P.+ 3,132 mm (4 mm decrease since 16:00 on January 6)
	Water level of Reactor Building	O.P.+ 4,240 mm (4 mm decrease since 16:00 on January 6)	O.P.+ 3,296 mm (12 mm decrease since 16:00 on January 6)	O.P.+ 3,394 mm (8 mm decrease since 16:00 on January 6)	O.P.+ 3,146 mm (8 mm decrease since 16:00 on January 6)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,038 mm (Increase from initial level:4,255 mm, 62 mm increase since 16:00 on January 6) O.P.+ 3,444 mm (Increase from initial level:4,170 mm, 136 mm increase since 16:00 on January 6) O.P.+ 4,433 mm (Water level from floor:637 mm, 8 mm increase since 16:00 on January 6)		
Situation of transfer of the accumulated water		—	Basement of Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building / High Temperature Incinerator Building) Currently being transferred (Since 9:30 on January 5)	Basement of Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building / High Temperature Incinerator Building) Currently being transferred (Since 10:01 on January 3)	—
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 8:58 on December 20   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 14:48 on January 4   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.