

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on January 7)**

		Unit 1	Unit 2	Unit 3	Unit 4
Water Level of the accumulated water (at 16:00 on January 7)	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,173 mm (7 mm decrease since 7:00 on January 7)	O.P.+ 3,172 mm (4 mm decrease since 7:00 on January 7)	—
	Water level of Turbine Building	O.P.+ 3,071 mm (7 mm increase since 7:00 on January 7)	O.P.+ 3,147 mm (6 mm decrease since 7:00 on January 7)	O.P.+ 3,119 mm (6 mm decrease since 7:00 on January 7)	O.P.+ 3,125 mm (7 mm decrease since 7:00 on January 7)
	Water level of Reactor Building	O.P.+ 4,237 mm (3 mm decrease since 7:00 on January 7)	O.P.+ 3,291 mm (5 mm decrease since 7:00 on January 7)	O.P.+ 3,390 mm (4 mm decrease since 7:00 on January 7)	O.P.+ 3,142 mm (4 mm decrease since 7:00 on January 7)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,076 mm (Increase from initial level:4,293 mm, 38 mm increase since 7:00 on January 7) O.P.+ 3,541 mm (Increase from initial level:4,267 mm, 97 mm increase since 7:00 on January 7) O.P.+ 4,438 mm (Water level from floor:642 mm, 5 mm increase since 7:00 on January 7)		
Situation of transfer of the accumulated water		—	Basement of Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building / High Temperature Incinerator Building) Currently being transferred (Since 9:30 on January 5)	Basement of Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building / High Temperature Incinerator Building) Currently being transferred (Since 10:01 on January 3)	—
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 8:58 on December 20 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 14:48 on January 4 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.