

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on January 8)**

		Unit 1	Unit 2	Unit 3	Unit 4
Water Level of the accumulated water (at 7:00 on January 8)	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,160 mm (13 mm decrease since 16:00 on January 7)	O.P.+ 3,164 mm (8 mm decrease since 16:00 on January 7)	—
	Water level of Turbine Building	O.P.+ 3,081 mm (10 mm increase since 16:00 on January 7)	O.P.+ 3,135 mm (12 mm decrease since 16:00 on January 7)	O.P.+ 3,110 mm (9 mm decrease since 16:00 on January 7)	O.P.+ 3,125 mm (No change since 16:00 on January 7)
	Water level of Reactor Building	O.P.+ 4,229 mm (8 mm decrease since 16:00 on January 7)	O.P.+ 3,278 mm (13 mm decrease since 16:00 on January 7)	O.P.+ 3,381 mm (9 mm decrease since 16:00 on January 7)	O.P.+ 3,134 mm (8 mm decrease since 16:00 on January 7)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,139 mm (Increase from initial level:4,356 mm, 63 mm increase since 16:00 on January 7) O.P.+ 3,716 mm (Increase from initial level:4,442 mm, 175 mm increase since 16:00 on January 7) O.P.+ 4,446 mm (Water level from floor:650 mm, 8 mm increase since 16:00 on January 7)		
Situation of transfer of the accumulated water		—	Basement of Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building / High Temperature Incinerator Building) Currently being transferred (Since 9:30 on January 5)	Basement of Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building / High Temperature Incinerator Building) Currently being transferred (Since 10:01 on January 3)	—
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 8:58 on December 20 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 14:48 on January 4 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.