

Situation of water level, transfer and treatment of the accumulated water in Fukushima Daiichi Nuclear Power Station (at 18:00 on January 8)

		Unit 1	Unit 2	Unit 3	Unit 4
Water Level of the accumulated water (at 16:00 on January 8)	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,183 mm (23 mm increase since 7:00 on January 8)	O.P.+ 3,166 mm (2 mm increase since 7:00 on January 8)	—
	Water level of Turbine Building	O.P.+ 3,087 mm (6 mm increase since 7:00 on January 8)	O.P.+ 3,156 mm (21 mm increase since 7:00 on January 8)	O.P.+ 3,125 mm (15 mm increase since 7:00 on January 8)	O.P.+ 3,112 mm (13 mm decrease since 7:00 on January 8)
	Water level of Reactor Building	O.P.+ 4,226 mm (3 mm decrease since 7:00 on January 8)	O.P.+ 3,291 mm (13 mm increase since 7:00 on January 8)	O.P.+ 3,391 mm (10 mm increase since 7:00 on January 8)	O.P.+ 3,130 mm (4 mm decrease since 7:00 on January 8)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,153 mm (Increase from initial level:4,370 mm, 14 mm increase since 7:00 on January 8) O.P.+ 3,558 mm (Increase from initial level:4,284 mm, 158 mm decrease since 7:00 on January 8) O.P.+ 4,450 mm (Water level from floor:654 mm, 4 mm increase since 7:00 on January 8)		
Situation of transfer of the accumulated water		—	Basement of Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building / High Temperature Incinerator Building) Transfer suspended (Since 9:27 on January 8)	Basement of Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building / High Temperature Incinerator Building) Transfer suspended (Since 9:31 on January 8)	—
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 8:58 on December 20 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 14:48 on January 4 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.