

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on January 9)**

		Unit 1	Unit 2	Unit 3	Unit 4
Water Level of the accumulated water (at 7:00 on January 9)	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,156 mm (27 mm decrease since 16:00 on January 8)	O.P.+ 3,159 mm (7 mm decrease since 16:00 on January 8)	—
	Water level of Turbine Building	O.P.+ 3,099 mm (12 mm increase since 16:00 on January 8)	O.P.+ 3,131 mm (25 mm decrease since 16:00 on January 8)	O.P.+ 3,092 mm (33 mm decrease since 16:00 on January 8)	O.P.+ 3,113 mm (1 mm increase since 16:00 on January 8)
	Water level of Reactor Building	O.P.+ 4,226 mm (No change since 16:00 on January 8)	O.P.+ 3,285 mm (6 mm decrease since 16:00 on January 8)	O.P.+ 3,370 mm (21 mm decrease since 16:00 on January 8)	O.P.+ 3,130 mm (No change since 16:00 on January 8)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,289 mm (Increase from initial level:4,506 mm, 136 mm increase since 16:00 on January 8) O.P.+ 3,723 mm (Increase from initial level:4,449 mm, 165 mm increase since 16:00 on January 8) O.P.+ 4,459 mm (Water level from floor:663 mm, 9 mm increase since 16:00 on January 8)		
Situation of transfer of the accumulated water		—	Basement of Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building / High Temperature Incinerator Building) Currently transferred (From 21:47 on January 8 to 8:05 on January 9)	Basement of Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building / High Temperature Incinerator Building) Currently transferred (From 21:37 on January 8 to 8:07 on January 9)	—
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 8:58 on December 20 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 14:48 on January 4 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.