

# **Situation of water level, transfer and treatment of the accumulated water in Fukushima Daiichi Nuclear Power Station (at 18:00 on January 9)**

		Unit 1	Unit 2	Unit 3	Unit 4
Water Level of the accumulated water (at 16:00 on January 9)	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,183 mm (27 mm increase since 7:00 on January 9)	O.P.+ 3,157 mm (2 mm decrease since 7:00 on January 9)	—
	Water level of Turbine Building	O.P.+ 3,104 mm (5 mm increase since 7:00 on January 9)	O.P.+ 3,154 mm (23 mm increase since 7:00 on January 9)	O.P.+ 3,114 mm (22 mm increase since 7:00 on January 9)	O.P.+ 3,105 mm (8 mm decrease since 7:00 on January 9)
	Water level of Reactor Building	O.P.+ 4,227 mm (1 mm increase since 7:00 on January 9)	O.P.+ 3,291 mm (6 mm increase since 7:00 on January 9)	O.P.+ 3,379 mm (9 mm increase since 7:00 on January 9)	O.P.+ 3,123 mm (7 mm decrease since 7:00 on January 9)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,313 mm (Increase from initial level:4,530 mm, 24 mm increase since 7:00 on January 9) O.P.+ 3,567 mm (Increase from initial level:4,293 mm, 156 mm decrease since 7:00 on January 9) O.P.+ 4,466 mm (Water level from floor:670 mm, 7 mm increase since 7:00 on January 9)		
Situation of transfer of the accumulated water		—	Transfer suspended	Transfer suspended	—
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 8:58 on December 20   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 14:48 on January 4   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.