

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on January 10)**

		Unit 1	Unit 2	Unit 3	Unit 4
Water Level of the accumulated water (at 16:00 on January 10)	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,124 mm (33 mm decrease since 7:00 on January 10)	O.P.+ 3,151 mm (No change since 7:00 on January 10)	—
	Water level of Turbine Building	O.P.+ 3,121 mm (6 mm increase since 7:00 on January 10)	O.P.+ 3,100 mm (30 mm decrease since 7:00 on January 10)	O.P.+ 3,105 mm (21 mm increase since 7:00 on January 10)	O.P.+ 3,097 mm (10 mm decrease since 7:00 on January 10)
	Water level of Reactor Building	O.P.+ 4,227 mm (1 mm decrease since 7:00 on January 10)	O.P.+ 3,258 mm (28 mm decrease since 7:00 on January 10)	O.P.+ 3,373 mm (10 mm increase since 7:00 on January 10)	O.P.+ 3,116 mm (6 mm decrease since 7:00 on January 10)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,646 mm (Increase from initial level:4,863 mm, 174 mm increase since 7:00 on January 10) O.P.+ 3,695 mm (Increase from initial level:4,421 mm, 75 mm decrease since 7:00 on January 10) O.P.+ 4,482 mm (Water level from floor:686 mm, 6 mm increase since 7:00 on January 10)		
Situation of transfer of the accumulated water		—	Basement of Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 8:17 on January 10)	Transfer suspended	—
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 8:58 on December 20 Suspended 2nd Cesium Adsorption Apparatus (Sarry): From 14:48 on January 4 to 9:25 on January 10 Operation, Since 13:04 on January 10 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.