

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on January 11)**

|   |  | Unit 1   | Unit 2   | Unit 3   | Unit 4   |
|---|--|--|--|--|--|
| Water Level of the accumulated water<br>(at 7:00 on January 11) | Water level of Vertical Shaft  | Unmeasurable due to drawdown of water level<br>(Less than O.P.+ 850 mm)  | O.P.+ 3,065 mm<br>(59 mm decrease since 16:00 on January 10)   | O.P.+ 3,164 mm<br>(13 mm increase since 16:00 on January 10) | —  |
|   | Water level of Turbine Building  | O.P.+ 3,133 mm<br>(12 mm increase since 16:00 on January 10)   | O.P.+ 3,047 mm<br>(53 mm decrease since 16:00 on January 10)   | O.P.+ 3,123 mm<br>(18 mm increase since 16:00 on January 10) | O.P.+ 3,107 mm<br>(10 mm increase since 16:00 on January 10) |
|   | Water level of Reactor Building  | O.P.+ 4,224 mm<br>(3 mm decrease since 16:00 on January 10)  | O.P.+ 3,207 mm<br>(51 mm decrease since 16:00 on January 10)   | O.P.+ 3,394 mm<br>(21 mm increase since 16:00 on January 10) | O.P.+ 3,122 mm<br>(6 mm increase since 16:00 on January 10)  |
|   | Water level of each building in the Centralized Radiation Waste Treatment Facility | Process Main Building<br>High Temperature Incinerator Building<br>On-site Bunker Building  | O.P.+ 3,974 mm (Increase from initial level:5,191 mm, 328 mm increase since 16:00 on January 10)<br>O.P.+ 3,109 mm (Increase from initial level:3,835 mm, 586 mm decrease since 16:00 on January 10)<br>O.P.+ 4,494 mm (Water level from floor:698 mm, 12 mm increase since 16:00 on January 10) |  |  |
| Situation of transfer of the accumulated water                  |  | —  | Basement of Turbine Building<br>→Centralized Radiation Waste Treatment Facility (Process Main Building)<br>Currently being transferred<br>(Since 8:17 on January 10)   | Transfer suspended   | —  |
| Operation condition of water treatment facility                 |  | Cesium Adsorption Apparatus: Since 8:58 on December 20   Suspended<br>2nd Cesium Adsorption Apparatus (Sarry): Since 13:04 on January 10   In operation<br>Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance<br>Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance |  |  |  |
| Notes   |  |  |  |  |  |

For quick publication of the data of water level, values are provided as reference values.